

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213808  
Address: 3817 SW MARYVILLE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Patrick Schonfeldt	Failed	Thursday, June 09, 2022

Corrective Action Required:

1	Misc	(1) PIER OK ON RIGHT SOUTH SIDE
		(1) PIER AT LEFT NORTH SIDE, MIN 36" DEPTH FOR FROST DEPTH FROM GRADE

**Comments:**