

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220011  
Address: 3542 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Thursday, June 09, 2022

Corrective Action Required:

1 Misc

-address CS-PF portal bracing at master bed windows per plans, see plans/IRC R602.10.6.4 for reference, dbl 2x12 header with trimmer studs, king studs, plates, tension straps, nail pattern exterior sheathing per design (NOT DONE, SEE DETAIL S2.0 IN PLANS)

**Comments:**