CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216206

Address: 109 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Thursday, June 09,

Residential 2022

Informational:

1 Misc **5/24/22-2nd not ready

-Provide complete, approved, stamped plans

Corrective Action Required:

2 Miscellaneous -Nail exterior wall sheathing per code

Correction -Provide (2) 2x6 cedar support to ridge beam front porch per plan

-Provide nut & washer at through bolt great room [remove insulation for

inspection]

-Provide CS-PF bracing dining room -Provide vent to roof kitchen sink

-Address (3) NM conductors through same bore kitchen

(3) NM conductors staples together on stud

Kitchen

Comments: