



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100272, Building Permit - Commercial
Address: 346 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Monday, January 31, 2011

Corrective Action Required

1 MISC

FASTENING OF LIGHT-GUAGE STEEL FRAMING: SCREW ALL FLANGES (INCLUDING AT CRIPPLES) WITHIN WIDTH OF ALL OPENINGS

Corrective Action Required

2 MISC

BACKING REQUIRED FOR THREE GRAB BARS AT RESTROOM

Corrective Action Required

3 MISC

ACCESS FOR INSPECTION: DOORS LOCKED; NO ACCESS TO INTERIOR

Comments: CALL TO REQUEST INSPECTION ON ANOTHER DAY