

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212483
Address: 2114 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, June 10, 2022

Corrective Action Required:

1	Miscellaneous Correction	Basement finish <ul style="list-style-type: none">- Fire block above electrical panel- Fire block foam gaps in soffit near window- Add more support for soffit over 4'- Fire block gaps in vertical FB through out- Fire block penetration at top plate garage wall- Provide Boca plates DWV in closet- Fire block penetration top plate bedroom 6 back wall
---	--------------------------	--

Comments: