

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20214592  
Address: 805 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
807 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
809 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Partial	Friday, June 10, 2022

Corrective Action Required:

1	Misc	<b>**BASEMENT FINISH INSPECTED</b>
		809: -Expose underslab plumbing for inspection and terminate all abandoned plumbing  <b>**OK TO ROCK</b>
		807: -Expose underslab plumbing for inspection and terminate all abandoned plumbing  <b>**OK TO ROCK</b>
		805: -Expose underslab plumbing for inspection and terminate all abandoned plumbing  <b>**OK TO ROCK</b>

**Comments:**