

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220011
Address: 3542 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Not Ready	Friday, June 10, 2022

Corrective Action Required:

1	Misc	-address CS-PF portal bracing at master bed windows per plans, see plans/IRC R602.10.6.4 for reference, dbl 2x12 header with trimmer studs, king studs, plates, tension straps, nail pattern exterior sheathing per design (NOT DONE, SEE DETAIL S2.0 IN PLANS)
---	------	---

Comments: