

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215330  
Address: 1752 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector: | Outcome: | Date:                 |
|-------------------------------------------|------------|----------|-----------------------|
| <b>Gas Piping Inspection - Commercial</b> | Robb Popp  | Partial  | Monday, June 13, 2022 |

Corrective Action Required:

|   |      |                                                    |
|---|------|----------------------------------------------------|
| 1 | Misc | -Paint new gas line with corrosion resistant paint |
|---|------|----------------------------------------------------|

**Comments:**