

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214881
Address: 4401 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|-----------------------|
| All Rough Inspection - Residential | Shawn Hoffman | Failed | Monday, June 13, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -nail stud shoes master bath vanity -covered front porch, rafters landing on blocks above top plate -provide (4) 2x4 stud packs at all girder truss bearing ends per plans -toenail all floor joists per code -provide joist hanger at joist to dbl rim connection above left side window basement -provide dbl 2x10 joist at N side basement per plans |
|---|------|--|

Comments: