



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20100324, Building Permit - Commercial  
Address: 2818 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Tuesday, February 01, 2011

### Corrective Action Required

1	MISC	TABLE 310.16 -DERIVED PHASED CONDUCTORS-1/0 ALUM ONLY OK FOR MAX. 125 AMP BREAKER AS ALLOWD PER 240.4
---	------	---

**Comments:** 200 AMP SERVICE OK FOR RELEASE.