

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211762
Address: 4724 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, June 13, 2022

Corrective Action Required:

1	Misc	-Provide combustion air openings per code **Not done. The space is not min 50 cubic ft per 1K btu of gas thermal input (furnace+water heater); therefore, combustion air openings are required. The submitted combustible air opening calculation letter requires 160 sq inches for each opening.
---	------	--

Comments: