



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100267, Building Permit - Commercial
Address: 930 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Not Ready	Thursday, February 03, 2011

Corrective Action Required
1 MISC

ACCESSIBLE COMMERCIAL RESTROOM REQUIRES:
1) NON-ABSORBENT FINISH ON RESTROOM WALL, BASE, AND FLOOR (CRACK MUST BE FILLED)
2) ADA/ANSI ACCESSIBLE SIGN

Comments: NO ACCESS TO STORE (STORE CLOSED). RESCHEDULE THE INSPECTION