



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20100207, Building Permit - Commercial  
Address: 3340 NE RALPH POWELL RD, Unit:A, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Partial	Friday, February 04, 2011

Partial Correction  
1 MISC

WRAP AROUND FURNACE PVC COMBUSTION AIR/EXHAUST  
PIPES WITH LISTED MATERIAL FOR ENVIROMENT AIR HANDLING  
SPACE

\*OK TO DROP CEILING TILES

**Comments:**