



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100272, Building Permit - Commercial
Address: 346 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Passed	Friday, February 04, 2011

Comments: NO ISSUES FOUND ON INSTALLATION OF K-BRACING TO REPLACE EXISTING X-BRACING AT WALL SEPARATING UPPER AND LOWER FLOOR AREAS.