



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20100308, Building Permit - Commercial  
Address: 880 NW BLUE PKWY, Unit:I, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Friday, February 04, 2011

Corrective Action Required

1	MISC	PADDING AT PIPING UNDER SINK PER ADA
2	MISC	LABEL GAS SERVICE ENTRY PER DISCUSSION
3	MISC	PERMANENT LABEL AT ELECTRICAL SERVICE METER
4	MISC	ANSI/ADA SIGN AT RESTROOM
5	MISC	EMERGENCY EGRESS LIGHT REQUIRED OUTSIDE FRONT ENTRANCE.

<b>Alarm Test</b>	Joe Dir	Passed	Friday, February 04, 2011
-------------------	---------	--------	---------------------------

<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Friday, February 04, 2011
--	---------	--------	---------------------------

Corrective Action Required

1

**Comments: OK TO SET UP FOR BUSINESS**

