

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Tuesday, June 14, 2022

Corrective Action Required:

1 FIRST FLOOR

Corrective Action Required:

2 SECOND FLOOR AREA "A" UNITS AND CORRIDORS:

201-207- OK

235-secure sec, complete exhaust fan wiring

236-complete rated layer in laundry, Secure sec, complete exhaust fan wiring

237-ok

238-strap top plates at beam lapped less than 48"

240-strap exterior wall top plates lapped less than 48"

242-strap exterior corners and header, strap corridor wall at shower, protect dwv, fireblock ceiling line at corridor, remove bonding screw,

239- strap over bored top plate at bedroom/208, strap exterior corner, strap top plate at closet lapped less than 48"

Corrective Action Required:

3 THIRD FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

Comments: