

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216160
Address: 2102 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, June 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	-No pier inspection on record -Missing H2.5s covered patio -Provide 4x4 cedar post to ridge beam front porch per plan -Replace blocking at cantilever (gas line) -Provide flashing above horizontal exterior trim above windows
---	--------------------------	---

Comments: