

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20212031  
Address: 3045 NW THOREAU LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ronald Paynter	Passed	Tuesday, June 14, 2022

Corrective Action Required:

1	Misc	Sidewalk has a soft spot on south side near existing sidewalk, will need dug out and compacted. Also has standing water on north side very near property line, will need drained before pouring(both areas marked with paint). All forms are in place and aggregate is compacted outside of those 2 areas. 6/8/22 ES
---	------	---

Informational:

2	Misc	Sidewalk was poured without a reinspection. Unsure if two questionable spots were corrected prior to placement. 6/13/22 ES
---	------	--

**Comments:**