

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215330  
Address: 1752 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Wednesday, June 15, 2022

Corrective Action Required:

1	Misc	-Provide anti-siphon device at hose bib -Complete bathrooms -Paint roof top gas line
---	------	--

\*\*\*OK TO STOCK ONLY

Comments: