

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214339
Address: 2126 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, June 15, 2022

Corrective Action Required:

1	Misc	**Repair erosion control along the street -As-graded plot plan is required -Final grade, sod, downspout and sump pump extension -Provide sewer tracer wire port at grade -Provide a readily accessible receptacle at grade and within 6.5 ft of grade at rear of house -Screw the exterior deck door embedded jamb brace into studs -Provide 5/8" GB under garage boxed out wall -Provide gfci protection for clothes washer outlet -Support ducting in basement -Securely fasten NM wiring at max 4.5 ft near basement smoke alarm -Label one unlabeled breaker
---	------	---

Comments: