

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20216366

Address: 3635 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:WTR, LEES SUMMIT,  
MO 640643695 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643635 NE AKIN DR,  
Unit:A, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                    | Inspector: | Outcome: | Date:                       |
|--------------------------------|------------|----------|-----------------------------|
| <b>Pavement-Aggregate Base</b> | Adam Nacke | Partial  | Wednesday, June 15,<br>2022 |

Informational:

1 Misc

2-4-22 AN spoke with travis walker about the drive approach and road going through the townhomes. Plans state the road and approach is 6" concrete 4" base witch is good for the road but the approach needs to be 4" base and 8" concrete

Informational:

2 Misc

5-26-22 AN. Crew is not working today because of rain. About 3/4 of the geo grid and aggregate base is down

6-15-22 AN all of the geo grid , type base is down and compacted

**Comments:**