

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204561
Address: 211 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, June 15, 2022

Corrective Action Required:

1 Miscellaneous
Correction

- Label non gfci outlets
- Provide security screws in door
- Nail off deck joist hangers
- Support CSST gas line under deck.
- Provide handrail for stairs from basement to pool
- guard rail required if level change over 30" by pool and steps (I Have confirmed this)

Comments: