

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202008
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
ESC - (Vegetation/Ground Cover)	Ronald Paynter	Partial	Wednesday, June 15, 2022

Corrective Action Required:

1	Misc	Large portion of plot remains not vegetated. Including entire hillside between Patch Ct and O'Brien going down towards creek. 6/6/22 ES
		Welch silt fence was onsite putting seed, straw, and silt fence down. 6/7/22 ES
		Vegetation has began to establish in areas where Welch treated last week and has started to grow down the hillside for the sewer running down creek to tie in point. 6/15/22 ES

Comments: