

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary

Certificate of Occupancy

Permit #: **PRRES20210590**
Address: **2114 NW ASHURST DR, LEES SUMMIT, MO 64081**
Inspected On: **Wednesday, June 15, 2022**
Inspected By: **Shawn Hoffman**
Expiration Date: **7/15/2022 12:00:00 AM**

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Temporary C of O	Wednesday, June 15, 2022

Corrective Action Required:

1	Miscellaneous Correction	Lower water meter lid to grade level Top of water meter to pit lid shall be 14" to 18"
---	-----------------------------	---

*****TCO EXPIRES 7/15/2022*****