

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211220
Address: 2125 NW ASHURST DR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, June 15, 2022
Inspected By: Shawn Hoffman
Expiration Date: 7/15/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Temporary C of O	Wednesday, June 15, 2022

Corrective Action Required:

- | | | |
|---|-----------------------------|---|
| 1 | Miscellaneous
Correction | - Provide Through bolts on deck 2@1/2" On each post to beam connections
- Security screws in hinges of exterior doors
- Provide 6" clearance from Siding to grade
TCO expiration 7/15/2022 |
|---|-----------------------------|---|