CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Robb Popp Partial Wednesday, June 15,

Commercial 2022

Corrective Action Required:

1 Miscellaneous -Provide fire collars at 2008,3008,4008,5008

Correction
Corrective Action Required:

2 SECOND FLOOR : THE FOLLOWING AREAS ARE APPROVED :

- 2ND FLOOR AREA A

- UNITS 2021,2022,2023,2024,2025,2027,2029,2004,2005,2006

**2008-Provide fire collars at dwv in chase

Corrective Action Required:

THIRD FLOOR: THE FOLLOWING AREAS ARE APPROVED:

:: 3ND FLOOR AREA A :

3004,3005,3006,3021,3022,2023,3024,3025,3027, 3029

**3008-Provide fire collars at dwv in chase

Corrective Action Required:

4 FOURTH FLOOR THE FOLLOWING AREAS ARE APPROVED:

::AREA A:

4004-4006,4021-4025,4027,4029
**Provide fire collars at dwv in chase

Corrective Action Required:

5 FIFTH FLOOR AREA "A"

THE FOLLOWING AREAS ARE APPROVED:

Corridor 7 to BUILDING B OK FOR RC CHANNEL

5004-5006,5021-5025,5027,5029

***5008-Provide fire collars at roof drains in chase

Comments: