

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214416  
Address: 540 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line Construction Inspection</b>	John Jackson	Passed	Thursday, June 16, 2022

Informational:  
1 Misc 11/09/21 Tuesday (ESS)  
Contractor installed Backflow Preventer Vault.

Informational:  
2 Misc 06/16/22 Thursday ( ESS)  
Contractor flushed out fire line as required.

**Comments:**