

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214416
Address: 540 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line Construction Inspection	John Jackson	Passed	Thursday, June 16, 2022

Informational:

1	Misc	11/09/21 Tuesday (ESS) Contractor installed Backflow Preventer Vault. 11/12/21 Friday Contractor working on the installation of fire line 6" PVC (C-900) as per plan. 11/15/21 Monday (ESS) Contractor is tie-in to the existing water main with and 8"x6" Tee and a valve. 2/45 deg bends, sleeve and approximately 25' of 6" water main to Backflow preventer. I called the Water Dept. for the 3/4 tap for the Chlorination & hydrostatic required. The first part of the hydrostatic test pass.
---	------	---

Comments: