

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210729
Address: 2159 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, June 16, 2022

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">- Gfci outlet on porch not tripping, tester shows hot and neutral reverse- Label non gfci outlets- Open electrical wiring above stove- Sump discharge minimum of 36" from foundation- Provide splash blocks- 6" clearance from siding to grade- Final grading and sod- irrigation permit and back flow certification if installed
---	--------------------------	--

Comments: