

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216315
Address: 3216 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, June 16, 2022

Corrective Action Required:

1	Misc	-fire block fire block furr down ceiling in garage from front garage wall -address hanger above great room windows -address triple trimmer at fire place bored to close to edge -fireblock dead space -missing hangers on 2nd floor
---	------	---

Comments: