

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211516
Address: 2350 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Diana Johnson	Passed	Thursday, June 16, 2022

Informational:

1 Misc

On Wednesday 12.08.2021 I performed a sidewalk inspection and pass the sub-grade to pour concrete.

On 6.16.2022 the sidewalk appears to be in compliance with City & ADA standards

Comments: