

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Thursday, June 16, 2022

Corrective Action Required:

1 THIRD FLOOR : THE FOLLOWING AREAS ARE APPROVED :

****AREA A****

- RC CHANNEL AT UNITS AND CORRIDOR TO AREA B
- AREA A SCREW PATTERN CORRIDOR LID TO UNIT 3022
- PROVIDE FIRE COLLARS AT ROOF DRAINS IN CHASE AT 3008

Corrective Action Required:

2 STAIR TOWER 1 : STAIRWAY 1 # 2003

Corrective Action Required:

3 STAIR TOWER 2 : STAIRWAY 2 # 2009 AREA A

Corrective Action Required:

4 SECOND FLOOR THE FOLLOWING AREAS ARE APPROVED

****AREA A****

- RC CHANNEL AT UNITS AND CORRIDOR TO AREA B
- SCREW PATTERN AT CORRIDOR LID
- SCREW PATTERN AT UNITS 2021,2022,2024,2027,2029,2004,2005,2006, 2008 AND CORRIDOR TO LOBBY 2001
- PROVIDE FIRE COLLARS AT ROOF DRAINS IN CHASE AT 2008

Corrective Action Required:

5 FOURTH FLOOR : THE FOLLOWING AREAS ARE APPROVED :

****AREA A****

-RC CHANNEL CORRIDOR CEILING TO FIRE DOORS -

-RC CHANNEL AT UNITS: 4004-4006, 4008,4021-4025,4027,4029

- AREA A SCREW PATTERN CORRIDOR CEILING TO FIRE DOORS -

-RC CHANNEL Corridor 4007 walls from mechanical closet 4021 to lobby 4011

--PROVIDE FIRE COLLARS AT ROOF DRAINS IN CHASE AT 4008

Corrective Action Required:
6 Miscellaneous
 Correction

:::FIFTH FLOOR:::

:THE FOLLOWING AREAS ARE APPROVED:

****AREA "A"*****

-RC CHANNEL AT CORRIDOR CEILINGS TO AREA "B"

-RC CHANNEL AT UNITS 5004-5006,5008,5021-5025,5027,5029

--PROVIDE FIRE COLLARS AT ROOF DRAINS IN CHASE AT 5008

Corrective Action Required:
7 Misc

Comments: