

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213494
Address: 1518 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, June 16, 2022

Corrective Action Required:

1	Misc	-address piers poured without inspection -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -seal top of meter can, A/c disconnect and all other exterior penetrations -check water meter at time of final grade and sod -guard rail at front stoop where required by code -hardware at sliding back patio door -self closing device at garage owners entry
---	------	---

Comments: