

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215679
Address: 2036 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, June 16, 2022

Corrective Action Required:

1 Misc

- Uncover porch framing for inspection
- Address joists bored closer than 2" to bottom of joist throughout garage
- Sister over notched studs at exterior garage wall all locations (sisters stud to be full length)
- fireblock hvac chase
- Address holes in joists bored closer together than 2" and closer than 2" to bottom throughout kitchen

Comments: