

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216229
Address: 2030 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, June 16, 2022

Corrective Action Required:

1 Misc

- fire block hvac chase into furr down
- address over notched joist for dwv above great room/breakfast and hole bored closer than 2" to edge fix to engineer letter specifications
- address hip beam not landing on top plate master closet fix to engineer specifications

Comments: