

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215946
Address: 2112 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, June 16, 2022

Corrective Action Required:
1 Misc

- address rafter to ceiling joist connection and rafters landing on blocks throughout
- mid way strap all dwv 2" in diameter or less
- land all electrical at back patio area
- uncover covered patio to inspect rafter to ceiling joist connection
- fire block to ceiling space right and left of fire place
- seal gaps in fire blocking at fire place
- provide proper slope to dwv above master bath (provide proper support
- strike plates for electrical in basement office some still missing
- fire block furr down end in bed 3 closet(if using Unfaced insulation it must be packed tightly and securely)

Comments: