

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216411
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line - Hydrostatic Test	Eric Sharp	Passed	Thursday, June 16, 2022

Informational:
1 Misc Fire line was pumped up to 200psi and held pressure for 2 hours. After line passed it was chlorinated in preparation for Bac-T testing. 6/16/22 ES

Comments: