

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216411
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water - Material Verification	Eric Sharp	Passed	Thursday, June 16, 2022

Informational:

1	Misc	Had 6" C900 water pipe, two 6" epoxy gate valves, epoxy coated adapters, meter wells, meter lids/rings, backflow devices for domestic and irrigation lines, tracer wire, locate tape and curb stop valve risers delivered. 4/5/22 ES
		All water components used for completion of fire line, water taps, water service lines all approved products. C900 pipe, epoxy coated valves and fittings on fire line, and copper line for taps and poly tubing from copper on back of meters to building. 6/16/22 ES

Comments: