



RELEASE FOR
CONSTRUCTION
AS NOTED ON PLANS REVIEW
Development Services
LEE'S SUMMIT, MISSOURI

RE: P210273 - Juneau Townhomes - Osage

Site Information:

Project Customer: Clover & Hive Project Name:

Lot/Block: Subdivision: Osage

Model: Juneau Townhomes

Address: SW Pryor Rd

City: Lee's Summit State: MO

General Truss Engineering Criteria & Design Loads (Individual Truss Design Drawings Show Special Loading Conditions):

Design Code: IRC2018/TPI2014

Wind Code: ASCE 7-16 Wind Speed: 115 mph

Roof Load: 45.0 psf

Design Program: MiTek 20/20 8.5

Design Method: MWFRS (Envelope)/C-C hybrid Wind ASCE 7-16

Floor Load: N/A psf

Mean Roof Height (feet): 35

Exposure Category: C

No.	Seal#	Truss Name	Date
1	I52573251	A2	6/16/22

The truss drawing(s) referenced above have been prepared by
MiTek USA, Inc. under my direct supervision based on the parameters
provided by Premier Building Supply (Springhill, KS)20300 W 207th Street.

Truss Design Engineer's Name: Sevier, Scott

My license renewal date for the state of Missouri is December 31, 2023.

IMPORTANT NOTE: The seal on these truss component designs is a certification that the engineer named is licensed in the jurisdiction(s) identified and that the designs comply with ANSI/TPI 1. These designs are based upon parameters shown (e.g., loads, supports, dimensions, shapes and design codes), which were given to MiTek or TRENCO. Any project specific information included is for MiTek's or TRENCO's customers file reference purpose only, and was not taken into account in the preparation of these designs. MiTek or TRENCO has not independently verified the applicability of the design parameters or the designs for any particular building. Before use, the building designer should verify applicability of design parameters and properly incorporate these designs into the overall building design per ANSI/TPI 1, Chapter 2.



June 16, 2022

Job	Truss	Truss Type	Qty	Ply	Juneau Townhomes - Osage
P210273	A2	Roof Special Girder	2	2	IS2573251

Premier Building Supply

ID:DUjzAB0GCWoOJpyMsoTzLz3uah-PWJeqCuKqbNajyt4IC5yVgqFFJDR6puLcMoeiOz5hLZ


Job Reference (optional)

-0-11-0	4-4-4	7-11-5	12-7-13	15-4-4	17-6-0	19-7-12	22-4-3	27-0-11	30-7-12	35-0-0	35-11-0
0-11-0	4-4-4	3-7-1	4-8-7	2-8-7	2-1-12	2-1-12	2-8-7	4-8-7	3-7-1	4-4-4	0-11-0

REPAIR:
REMOVE PEAK FROM TRUSS AS SHOWN.

Scale = 1:62.9

NO REPAIR REQUIRED.



LUMBER AND CONNECTOR PLATES (SHOWN DASHED) TO BE CUT CLEANLY AND ACCURATELY AND THE REMAINING PLATE(S) MUST BE FULLY EMBEDDED AND UNDISTURBED.

	4-4-4	7-11-5	12-7-13	15-4-4	19-7-12	22-4-3	27-0-11	30-7-12	35-0-0
	4-4-4	3-7-1	4-8-7	2-8-7	4-3-8	2-8-7	4-8-7	3-7-1	4-4-4

Plate Offsets (X,Y)-- [2:0-8-0,0-0-4], [4:0-4-0,0-1-15], [6:Edge,0-1-2], [7:0-4-0,0-4-8], [8:0-2-0,Edge], [9:0-1-13,Edge], [11:0-4-0,0-1-15], [13:0-8-0,0-0-4]

LOADING (psf)	SPACING-	CSL	DEFL.	PLATES	GRIP
TCLL (roof) 25.0	2-0-0	TC 0.37	in (loc) l/defl L/d	MT20	197/144
Snow (Pf/Pg) 17.3/25.0	Plate Grip DOL 1.15	BC 0.72	Vert(LL) -0.23 19 >999 240		
TCDL 10.0	Lumber DOL 1.15	WB 0.31	Vert(CT) -0.37 19 >999 180		
BCLL 0.0 *	Rep Stress Incr NO	Matrix-SH	Horz(CT) 0.10 13 n/a n/a		
BCDL 10.0	Code IRC2018/TPI2014			Weight: 424 lb	FT = 20%

LUMBER-

TOP CHORD 2x4 SP No.2 *Except*
4-7-7-11: 2x6 SPF No.2
BOT CHORD 2x6 SPF No.2
WEBS 2x4 SP No.2

BRACING-

TOP CHORD Sheathed or 4-8-14 oc purlins, except
2-0-0 oc purlins (5-7-6 max.): 4-11.
BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
JOINTS 1 Brace at Jt(s): 7

REACTIONS.

(size) 2=0-3-8, 13=0-3-8
Max Horz 2=-95(LC 13)
Max Uplift 2=-638(LC 12), 13=-706(LC 13)
Max Grav 2=3288(LC 41), 13=3288(LC 41)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

TOP CHORD 2-24=-6111/1243, 24-25=-6012/1244, 3-25=-5922/1236, 3-26=-5698/1275,
26-27=-5650/1284, 4-27=-5591/1304, 4-28=-6969/1675, 28-29=-6971/1675,
29-30=-6974/1677, 5-30=-6982/1678, 5-31=-6973/1674, 6-31=-6973/1674, 6-7=-6686/1621,
7-9=-6686/1662, 9-32=-6973/1694, 10-32=-6973/1694, 10-33=-6982/1698,
33-34=-6974/1697, 11-34=-6971/1695, 6-8=-350/81, 8-9=-350/80, 11-35=-5591/1360,
35-36=-5650/1338, 12-36=-5698/1324, 12-37=-5922/1312, 37-38=-6012/1310,
13-38=-6111/1303
BOT CHORD 2-39=-1061/5266, 39-40=-1061/5266, 23-40=-1061/5266, 23-41=-1061/5266,
22-41=-1061/5266, 22-42=-1052/5083, 42-43=-1052/5083, 21-43=-1052/5083,
20-21=-1052/5083, 20-44=-1536/7334, 44-45=-1536/7334, 19-45=-1536/7334,
19-46=-1536/7334, 46-47=-1536/7334, 18-47=-1536/7334, 17-18=-1064/5083,
17-48=-1064/5083, 48-49=-1064/5083, 16-49=-1064/5083, 16-50=-1086/5266,
15-50=-1086/5266, 15-51=-1086/5266, 51-52=-1086/5266, 13-52=-1086/5266
WEBS 3-23=0/276, 3-22=-316/78, 4-22=-83/552, 4-20=-662/2487, 5-20=-1134/494,
7-20=-479/64, 7-19=0/363, 7-18=-469/60, 10-18=-1134/494, 11-18=-619/2487,
11-16=-77/552, 12-16=-316/68, 12-15=0/276

NOTES-

- 2-ply truss to be connected together with 10d (0.120"x3") nails as follows:
Top chords connected as follows: 2x4 - 1 row at 0-9-0 oc, 2x6 - 2 rows staggered at 0-9-0 oc.
Bottom chords connected as follows: 2x6 - 2 rows staggered at 0-9-0 oc.
Webs connected as follows: 2x4 - 1 row at 0-9-0 oc.
- All loads are considered equally applied to all plies, except if noted as front (F) or back (B) face in the LOAD CASE(S) section. Ply to ply connections have been provided to distribute only loads noted as (F) or (B), unless otherwise indicated.
- Unbalanced roof live loads have been considered for this design.
- Wind: ASCE 7-16; Vult=115mph (3-second gust) Vasd=91mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; Ke=0.96; Cat. II; Exp C; Enclosed; MWFRS (envelope) gable end zone; cantilever left and right exposed; end vertical left and right exposed; Lumber DOL=1.60 plate grip DOL=1.60
- TCLL: ASCE 7-16; Pr=25.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=25.0 psf; Pf=17.3 psf (Lum DOL=1.15 Plate DOL=1.15); Is=1.0; Rough Cat C; Fully Exp.; Ce=0.9; Cs=1.00; Ct=1.10, Lu=50-0-0; Min. flat roof snow load governs.

Unbalanced roof live loads have been considered for this design.

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.

Design valid for use only with Mitek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601



June 16, 2022



16023 Swingley Ridge Rd
Chesterfield, MO 63017

Job	Truss	Truss Type	Qty	Ply	Juneau Townhomes - Osage	I52573251
P210273	A2	Roof Special Girder	2	2	Job Reference (optional)	

Premier Building Supply

8.530 s Apr 27 2022 MiTek Industries, Inc. Thu Jun 16 13:59:38 2022 Page 2
ID:DUjzAB0GCWoOJpyMsoTzILz3uah-PWJeqCuKqbNajyt4IC5yVgqFFJDR6puLcMoeiOz5hLZ

NOTES-

- 7) This truss has been designed for greater of min roof live load of 12.0 psf or 2.00 times flat roof load of 17.3 psf on overhangs non-concurrent with other live loads.
- 8) Provide adequate drainage to prevent water ponding.
- 9) All plates are 3x4 MT20 unless otherwise indicated.
- 10) This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- 11) * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
- 12) Two H2.5T Simpson Strong-Tie connectors recommended to connect truss to bearing walls due to UPLIFT at jt(s) 2 and 13. This connection is for uplift only and does not consider lateral forces.
- 13) This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.
- 14) Graphical purlin representation does not depict the size or the orientation of the purlin along the top and/or bottom chord.
- 15) "NAILED" indicates 3-10d Nails (0.148" x 3") toe-nails per NDS guidelines.

LOAD CASE(S) Standard

1) Dead + Snow (balanced): Lumber Increase=1.15, Plate Increase=1.15

Uniform Loads (plf)

Vert: 1-4=-55, 4-6=-55, 9-11=-55, 6-8=-55, 8-9=-55, 11-14=-55, 2-13=-20

Concentrated Loads (lb)

Vert: 6=-189(F) 9=-189(F) 22=-155(F) 19=-35(F) 16=-155(F) 24=-128(F) 25=-114(F) 26=-39(F) 27=-79(F) 29=-189(F) 30=-189(F) 31=-189(F) 32=-189(F) 33=-189(F) 34=-189(F) 35=-79(F) 36=-39(F) 37=-114(F) 38=-128(F) 39=-121(F) 40=-111(F) 41=-168(F) 42=-35(F) 43=-35(F) 44=-35(F) 45=-35(F) 46=-35(F) 47=-35(F) 48=-35(F) 49=-35(F) 50=-168(F) 51=-111(F) 52=-121(F)

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 5/19/2020 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component**


Safety Information available from Truss Plate Institute, 2670 Crain Highway, Suite 203 Waldorf, MD 20601




16023 Swingley Ridge Rd
Chesterfield, MO 63017

Symbols

PLATE LOCATION AND ORIENTATION



Center plate on joint unless x, y offsets are indicated. Dimensions are in ft-in-sixteenths. Apply plates to both sides of truss and fully embed teeth.



For 4 x 2 orientation, locate plates 0- 1/16" from outside edge of truss.



This symbol indicates the required direction of slots in connector plates.


* Plate location details available in **MiTek 20/20** software or upon request.

PLATE SIZE

4 X 4


The first dimension is the plate width measured perpendicular to slots. Second dimension is the length parallel to slots.

LATERAL BRACING LOCATION



Indicated by symbol shown and/or by text in the bracing section of the output. Use T or I bracing if indicated.

BEARING




Indicates location where bearings (supports) occur. Icons vary but reaction section indicates joint number where bearings occur. Min size shown is for crushing only.

Industry Standards:

ANSI/TP1: National Design Specification for Metal Plate Connected Wood Truss Construction.
DSB-89: Building Component Safety Information, Guide to Good Practice for Handling, Installing & Bracing of Metal Plate Connected Wood Trusses.

Numbering System

6-4-8 dimensions shown in ft-in-sixteenths (Drawings not to scale)



JOINTS ARE GENERALLY NUMBERED/LETTERED CLOCKWISE AROUND THE TRUSS STARTING AT THE JOINT FARTHEST TO THE LEFT.

CHORDS AND WEBS ARE IDENTIFIED BY END JOINT NUMBERS/LETTERS.

PRODUCT CODE APPROVALS

ICC-ES Reports:

ESR-1311, ESR-1352, ESR1988
ER-3907, ESR-2362, ESR-1397, ESR-3282

Trusses are designed for wind loads in the plane of the truss unless otherwise shown.

Lumber design values are in accordance with ANSI/TP1 1 section 6.3 These truss designs rely on lumber values established by others.

© 2012 MiTek® All Rights Reserved



MiTek Engineering Reference Sheet: MII-7473 rev. 5/19/2020



General Safety Notes

Failure to Follow Could Cause Property Damage or Personal Injury

1. Additional stability bracing for truss system, e.g. diagonal or X-bracing, is always required. See BCSI.
2. Truss bracing must be designed by an engineer. For wide truss spacing, individual lateral braces themselves may require bracing, or alternative Tor I bracing should be considered.
3. Never exceed the design loading shown and never stack materials on inadequately braced trusses.
4. Provide copies of this truss design to the building designer, erection supervisor, property owner and all other interested parties.
5. Cut members to bear tightly against each other.
6. Place plates on each face of truss at each joint and embed fully. Knots and wane at joint locations are regulated by ANSI/TP1 1.
7. Design assumes trusses will be suitably protected from the environment in accord with ANSI/TP1 1.
8. Unless otherwise noted, moisture content of lumber shall not exceed 19% at time of fabrication.
9. Unless expressly noted, this design is not applicable for use with fire retardant, preservative treated, or green lumber.
10. Camber is a non-structural consideration and is the responsibility of truss fabricator. General practice is to camber for dead load deflection.
11. Plate type, size, orientation and location dimensions indicated are minimum plating requirements.
12. Lumber used shall be of the species and size, and in all respects, equal to or better than that specified.
13. Top chords must be sheathed or purlins provided at spacing indicated on design.
14. Bottom chords require lateral bracing at 10 ft. spacing, or less, if no ceiling is installed, unless otherwise noted.
15. Connections not shown are the responsibility of others.
16. Do not cut or alter truss member or plate without prior approval of an engineer.
17. Install and load vertically unless indicated otherwise.
18. Use of green or treated lumber may pose unacceptable environmental, health or performance risks. Consult with project engineer before use.
19. Review all portions of this design (front, back, words and pictures) before use. Reviewing pictures alone is not sufficient.
20. Design assumes manufacture in accordance with ANSI/TP1 1 Quality Criteria.
21. The design does not take into account any dynamic or other loads other than those expressly stated.