
DEVELOPMENT SERVICES

Building Permit - Commercial Project Title: THE LOCAL PIZZERIA Work Desc: CHANGE OF TENANT	Permit No: PRCOM20220646 Date Issued: June 16, 2022
---	--

Project Address: 805 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064 Legal Description: THE VILLAGES OF LAKEWOOD FAIRWAY HOMES VILLAGE SECTION ONE PT OF TR M DAF: BEG AT NE COR SO TR M TH NW ALG N LI SD TR 284.61' TO TRU POB TH S 27.62' TH SLY ALG CURV TO RI 71.06' TH SW 15.13' TH SLY ALG CURV TO LF 87.89' TH S 68' TH W 214' Parcel No: 43240020102100000 County: JACKSON	Permit Holder: D.I.G. CONSTRUCTION INC 9539 MANCHESTER AVE KANSAS CITY, MO 64134
---	--

Activities Included for this Project: zChange of Tenant, License Tax, License Tax Credit, Commercial Hood Permit, Fire Rated Assemblies Permit,

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITTED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS. NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

Fire Plan Review

2 M] 607.2 Where required. A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease vapors.

Exceptions:

1. Factory-built commercial exhaust hoods that are listed and labeled in accordance with UL 710, and installed in accordance with Section 304.1 of the International Mechanical Code, shall not be required to comply with Sections 507.1.5, 507.2.3, 507.2.5, 507.2.8, 507.3.1, 507.3.3, 507.4 and 507.5 of the International Mechanical Code.

2. Factory-built commercial cooking recirculating systems that are listed and labeled in accordance with UL 710B, and installed in accordance with Section 304.1 of the International Mechanical Code, shall not be required to comply with Sections 507.1.5,

507.2.3, 507.2.5, 507.2.8, 507.3.1, 507.3.3, 507.4 and 507.5 of the International Mechanical Code.

Spaces in which such systems are located shall be considered to be kitchens and shall be ventilated in accordance with Table 403.3.1.1 of the International Mechanical Code. For the purpose of determining the floor area required to be ventilated, each individual appliance shall be considered as occupying not less than 100 square feet (9.3 m²).

3. Where cooking appliances are equipped with integral down-draft exhaust systems and such appliances and exhaust systems are listed and labeled for the application in accordance with NFPA 96, a hood shall not be required at or above them.

4. A Type I hood shall not be required for an electric cooking appliance where an approved testing agency provides documentation that the appliance effluent contains 5 mg/m³ or less of grease when tested at an exhaust flow rate of 500 cfm (0.236 m³/s) in accordance with UL 710B.

Action required- Provide specifications for the hood and suppression systems for review and approval.

3 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required- Call (816) 969-1300 to schedule a test of the hood system.

Building Plan Review

2 For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

4/7/22 - not addressed

5/4/22 - acknowledged in letter

3 2018 IBC 1606.2 Design dead load. For purposes of design, the actual weights of materials of construction and fixed service equipment shall be used. In the absence of definite information, values used shall be subject to the approval of the building official.

Action required: Provide engineer's report and/or design to verify that existing roof structure will support additional load.

4/7/22 - not addressed for fan and makeup air unit

5/4/22 - deferred - Inspections not allowed to be scheduled until letter and/or strengthening design is received and approved.

Licensed Contractors

Signature of Applicant: _____	Date: _____
----------------------------------	-------------

Print name: _____

Company Name: _____