

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213588

Address: 3703 SW WALSH DR, LEES SUMMIT, MO 640823705 SW WALSH DR, LEES SUMMIT, MO 640823707
SW WALSH DR, LEES SUMMIT, MO 640823701 SW WALSH DR, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Friday, June 17, 2022

Corrective Action Required:

1	Misc	3701 OK
		3703 OK
		3705 OK
		3707: PROVIDE 4' FIRE RATED PLYWOOD AT ROOF DECK FIREWALL MASTER BEDROOM

Comments: