

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20202637  
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Partial	Friday, June 17, 2022

Corrective Action Required:

1	Misc	PRE FINAL
---	------	-----------

Area A

- Complete mister for dust collection and provide covers at machine hook ups in wood shop
- Provide restroom signage
- Complete restroom mirrors and access panels
- Provide all room signage
- Mechanical room-secure mc at switch, provide cover plates at BMS and at ceiling
- A108 seal gap outside of electrical outlet at sink,

A2

- 202,203- cover plates
- 215-remove covers on sprinkler heads
- 206-cover plates

**Comments:**