

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20210630  
Address: 2052 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Eric Sharp	Passed	Friday, June 17, 2022

Informational:	
1       Misc	Driveway is framed up with aggregate in place and compacted. Needs one section of curb replaced in front of drive. 11/12 ES

Corrective Action Required:	
2       Misc	Section of curb on the east side of driveway was never replaced. Section will need to be removed and a new section poured. 5/26/22 ES

Curb still hasn't been replaced. 6/6/22 ES

Informational:	
3       Misc	Wes with Pat Cochran patched the concern areas to a satisfactory condition. 6/17/22 ES

**Comments:**