

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213630
Address: 433 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, June 20, 2022

Corrective Action Required:

3	Misc	<ul style="list-style-type: none">- pay all fees- House numbers to be contrasting colors- Final grading and sod- Seal top of A/C disconnect- Provide cover for attic access- Handrail in garage at 40" R311.7.8.1 Handrail height 34-38"
---	------	---

Comments: