

David P. Ainsworth, P.E.
1200 NW Hearn Ave, Blue Springs, MO 64015
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

October 28, 2021

Mr. Mark Yancik
508 NW Manor Drive
Blue Springs, MO 64014

Re: 512 SE David Rd
Lee's Summit, MO
Lot 3
Kyle I Planset
Steel Beam Substitution for triple LVL

Dear Mr. Yancik:

Substitution of a W18x35 steel beam for the 3 @ 1.75" x 24" LVL's spanning from the Kitchen wall to the exterior Great Room Wall is acceptable.

The W18x35 steel beam is more than capable of supporting the imposed loads.

Cordially,



David P. Ainsworth, P.E.

