

Sprinkler Legend SYMBOL MANUFACTURER SIN MODEL QUANTITY K-FACTOR TYPE SIZE RESPONSE FINISH TEMPERATURE VK302 S.C. PENDENT 5.6 PENDENT 1/2 QUICK CHROME 155°F TOTAL = 31

ORDINARY HAZARD I WET SYSTEM

Lee's summit FM

DESIGNER AKC SCALE

DESIGN PROFESSIONAL OF RECORD

GENERAL FIRE PROTECTION NOTES & LEGEND

DESIGN IS BASED ON 2016 NFPA 13 FOR INSTALLATION & NFPA 25 FOR MAINTENANCE.
 ALL SPRINKLER MATERIAL TO COMPLY WITH UL LISTINGS, ALL AHJ REQUIREMENTS, AND NFPA

4. ALL VALVES TO BE MONITORED BY TAMPER SWITCHES.

5. ALL ELECTRICAL WIRING TO BE BY OTHERS.

6. ANY UNDERGROUND PIPE WORK TO BE BY OTHERS.7. ALL PAINTING OF SPRINKLER PIPE TO BE BY OTHERS.

10. THIS BUILDING IS UNOBSTRUCTED NONCOMBUSTIBLE CONSTRUCTION.

13. GROOVED PIPE OF DIAMETERS UP TO 4" TO BE BLACK DYNA FLOW. 14. GROOVED PIPE OF DIAMETERS OVER 4" TO BE BLACK SCHEDULE 10.

15. NEW PIPE TO BE 1" SCH 40 UNO 16. NEW WORK DOES NOT AFFECT HYDRAULICALLY REMOTE AREA.

11. ORIGINAL WET TYPE SYSTEM DESIGNED AT ORDINARY HAZARD.12. THREADED PIPE OF ANY DIAMETER TO BE BLACK SCHEDULE 40.

FIRE PROTECTION

130 W 9TH AVE. SUITE 101

NORTH KANSAS CITY, MO 64116 PH: 913-888-0647 FAX: 913-888-0618 PHA Consulting LLC

1530 Arrowridge DR Roach, MO 65787

Lee's Summit, MO

CONTRACTOR

Green Relief

205 NE 291 Highway

PROJECT

VARIES TOTAL SPRINKLERS ON JOB 31 JOB NUMBER FP 24930 DATE 06/09/22 SHEET NUMBER FP 1 OF 1