

**DEVELOPMENT SERVICES**

**Residential Plan Review**

June 20, 2022

Ecovole  
1444 grand blvd ste 1202  
kansas city, MO 64106  
(816) 351-7803

Permit No: PRRES20222063  
Plan Name:  
Project Address: 129 NW MACKENZIE DR, LEES SUMMIT, MO 64081  
Parcel Number: 62330040500000000  
Location: WINTERSET VALLEY 12TH PLAT LOTS 1435 THRU 1471 & TRACTS A12 THRU D12---LOT 1463  
Type of Work: ALTERATION SINGLE FAMILY  
Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY  
Description: ROOF MOUNTED SOLAR - 14.19 KW

***Revisions Required***

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.***

Development Services Department (816) 969-1200

**Residential Plan Review**                      **Reviewed By: Joe Frogge**                      **Rejected**

1. System exceeds 15KW.

Action required: Designs must be sealed/signed by Electrical Engineer.

**Fire Department Solar Review**                      **Reviewed By: Jim Eden**                      **Rejected**

1. Provide PE stamped plans.

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***

Residential Area:			
Roofing Material		Number of Bathrooms	
Number of Bedrooms		Number of Stories	
Number of Living Units		Total Living Area	

--	--	--	--