

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221724  
Address: 3219 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Shawn Hoffman	Partial	Tuesday, June 21, 2022

Corrective Action Required:

1	Misc	Pool bonding at 4 points copper ring all re bat mat tied, #4 from pump to cover box Good to pour bib
---	------	---

**Comments:**