

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210729
Address: 2159 NW KILLARNEY LN, LEES SUMMIT, MO 64081
Inspected On: Tuesday, June 21, 2022
Inspected By: Khanh Nguyen
Expiration Date: 7/21/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Tuesday, June 21, 2022

Corrective Action Required:

- | | | |
|---|-----------------------------|--|
| 1 | Miscellaneous
Correction | - Sump discharge minimum of 36" from foundation
- Provide splash blocks
- 6" clearance from siding to grade
- Final grading and sod
- irrigation permit and back flow certification if installed |
|---|-----------------------------|--|