

PERFECT PROMOTIONS

PROJECT ADDRESS:
1469 SW MARKET STREET
LEE'S SUMMIT, MO 64081



COPYRIGHT © 2022.
HIVE DESIGN COLLABORATIVE, INC.

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT ST., KANSAS CITY, MO 64108
816.581.6363



PERFECT PROMOTIONS

1469 SW Market Street
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.

1617 WALNUT STREET, KANSAS CITY, MO 64108
816 581 6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.



06.13.22

project number 2022-018

date 05.25.2022


issued for PERMIT

rev	date	description
-----	------	-------------

ACCESSIBILITY GUIDELINES

sheet number

G002



NOTES

GENERAL NOTES - ACCESSIBILITY GUIDELINES:

- NOTE: ALL DIMENSIONS ARE MEASURED FROM FLOOR, UNLESS NOTED OR SHOWN OTHERWISE.
- ADA UNOBSTRUCTED REACH RANGES: ADA FORWARD REACH = 48" MAX. & 15" MIN. ADA SIDE REACH = 48" MAX. & 15" MIN.
- ELEVATORS: STANDARD CATCH BUTTONS: 35" TO 42" TO C.L. (TYP.) & 1" MAX. ADA CATCH BUTTONS: 42" TO C.L. (TYP.) & 8" MAX. (34" SMALLEST DIM.). ADA VISIBLE SIGNALS: 72" MIN. TO C.L. (2" TYP. SMALLEST DIM.). TACTILE SIGNAL ON HOISTWAY: 60" TO BASE OF CHARACTERS W/ TACTILE STAR & 2" HIGH CHARACTERS.
- DOOR HARDWARE (TO CENTER OF HARDWARE): STANDARD MOUNTING HEIGHTS: PUSH PLATES = 42". PULL HANDLES = 42". KNOBS/ LEVERS = 40". PANIC EXIT = 48". CENTERLINE OF BAR, KICKPLATES: WIDTH = DOOR WIDTH MINUS 2". CENTER, HEIGHT = 16" FROM B.O. DOOR. THRESHOLDS: STANDARD = 1/2" MAX. AT EXIT, SLIDING DOORS = 3/4" MAX. ADA HARDWARE = 34" MIN. TO 48" MAX.
- DRINKING FOUNTAINS & EWC'S (TO SPOUT): STANDARD = 38" MIN., 43" MAX. ADA = 36" MAX. (27" MIN. CLEAR KNEE SPACE)
- COUNTERTOPS (TO SINK RIM/ COUNTERTOP): ADA = 28" MIN. TO 34" MAX.
- WATER CLOSETS (TO TOP OF SEAT): STANDARD = 14" TO 15". ADA (TO TOP OF SEAT) = 17" TO 19". ADA FLUSH CONTROLS = 44" MAX.
- UPSETS (TO RIM): STANDARD = 24" MAX. ADA = 17" MAX. ADA FLUSH CONTROLS = 44" MAX.
- LAVATORIES (TO SINK RIM/ COUNTERTOP): STANDARD = 36" MAX. ADA = 34" MAX. (29" MIN. CLEAR KNEE SPACE)
- MIRRORS (TO C.O. REFLECTIVE SURFACE): STANDARD = VARIES. ADA = 40" MAX.
- GRAB BARS - ADA (TO TOP OF BAR): WATER CLOSETS = 33" MIN. TO 36" MAX. SHOWERS = 33" MIN. TO 36" MAX. (TO B.O. SHOWER). BATHTUBS = 33" MIN. TO 33" MIN. TO 36" MAX. B.O. BAR = 9" ABOVE TUB.
- SHOWER HEADS (FROM FLOOR TO HEAD): STANDARD = 72" TO 84". ADA = SPRAY UNIT W/ HOSE 60" LONG MIN. ADA = FIXED SHOWER HEAD = 48" AFF.
- SHOWER CONTROLS (TO CONTROL AREA): STANDARD = 48" MAX. (TO TOP). ADA = 38" MIN. TO 48" MAX.
- SHOWER ROD (FROM FLOOR TO C.L.): STANDARD = 78" MAX.
- TOILET ROOM FUNCTIONS: TOILETS = 12" TO BOT. & 70" TO TOP. URINALS = 18" TO BOT. & 60" TO TOP.
- TOILET PAPER DISPENSERS (TO C.L. OF OUTLET): STANDARD = 24". ADA = 19" MIN. TO 24" MAX.
- WALL MOUNTED SOAP DISPENSERS (TO C. L. OF PUSH BUTTON): STANDARD = 40". ADA = VARIES. RE: OBSTRUCTED AND UNOBSTRUCTED REACH RANGES. ADA SIDE REACH = 48" MAX. ABOVE SINK INCOUNT. PAPER TOWEL DISPENSER WASTE RECEPTACLE (TO TOWEL SLOT): STANDARD = 40" MAX. ADA FORWARD REACH = 48" MAX. & 15" MIN. ADA SIDE REACH = 48" MAX. & 15" MIN.
- AIR HAND DRYER (TO PUSH SWITCH): STANDARD = 44" MAX. ADA FORWARD REACH = 48" MAX. & 15" MIN. ADA SIDE REACH = 48" MAX. & 15" MIN.
- SANITARY NAKPIN DISPENSER (TO C.L. OF CATCH SLOT): STANDARD 40" MAX. ADA FORWARD REACH = 48" MAX. & 15" MIN. ADA SIDE REACH = 48" MAX. & 15" MIN.
- SANITARY NAKPIN DISPOSAL (TO TOP OF UNIT): STANDARD = 28" MAX. ADA = 19" MIN. TO 24" MAX.
- TOILET SEAT COVER DISPENSERS (TO OPNG.): STANDARD = 40" MAX. ADA FORWARD REACH = 48" MAX. & 15" MIN. ADA SIDE REACH = 48" MAX. & 15" MIN.
- SHOES: ADA = 48" MAX.
- COAT HOOKS: STANDARD = 68". ADA = 48" MAX.
- CHALKBOARDS, TACKBOARDS & MARKERBOARDS: STANDARD = 32" TO 39" (TO FORWARD OR BACKSTRAY). STANDARD = 80" (RECOMMENDED, TO T.O. BOARD).
- THERMOSTATS & CONTROL DEVICES (TO TOP): ADA FORWARD REACH = 48" MAX. ADA SIDE REACH = 48" MAX.
- LIGHT SWITCHES & READERS (TO C.L.): STANDARD 5' FROM DOOR JAMB. ADA = 48" MAX.
- CONVENIENCE RECEPTACLES - ELECTRICAL/ TELEPHONE/ DATA (TO C.L.): STANDARD = 18". ADA = 15" MIN.
- EXIT LIGHTS - WALL MOUNTED: 2" MIN. BELOW CEILING. 2" MIN. ABOVE DOOR. FRAME, EQUAL SPACE FROM CEILING TO TOP OF FRAME.
- FIRE EXTINGUISHERS (TO TOP, U.O.): GROSS WT. 40 LBS. OR LESS = 60" MAX. NET WT. MORE THAN 40 LBS. = 42" MAX. ADA = 40" MAX. (B.O. CABINET).
- FIRE ALARM PULL STATIONS (TO LEVER): STANDARD = 48" MAX. ADA FORWARD REACH = 48" MAX. ADA SIDE REACH = 48" MAX.
- SMOKES AND/OR HEAT DETECTORS: STANDARD = CEILING HEIGHT.
- HORN/ SPEAKER/ VISUAL SIGNALS: STANDARD = 80" AFF. OR 6" BELOW CEILING - WHICHEVER IS LOWER.
- HIGH CONTRAST SIGNAGE (TO C.L.): STANDARD = 60" HIGH AFF. & WITHIN 18" OF LATCH SIDE OF DOOR.



PERFECT PROMOTIONS

1469 SW Market Street
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



06.13.22

project number 2022-018

date 05.25.2022

issued for PERMIT

rev	date	description
1	06/08/22	CITY COMMENTS

CODE PLAN

sheet number

G100

CODE PLAN LEGEND

ROOM OCCUPANT LOAD

101 ROOM NUMBER
ROOM NAME
150 SF SQUARE FEET OF SPACE OR ROOM
XXX ALLOWABLE NUMBER OF OCCUPANTS
XX EXIT WIDTH IN DECIMAL FEET

EXIT WIDTH FACTORS:

STAIRS: 0.3" PER OCCUPANT SERVED
DOORS: 0.2" PER OCCUPANT SERVED

FE FIRE EXTINGUISHER

CODE SYMBOL KEY

1/16" = 1'-0"

CODE INFORMATION SUMMARY:

SUBJECT	DATA	REFERENCE
PROJECT DESCRIPTION	RENOVATION OF AN EXISTING OFFICE SPACE FOR A NEW TENANT	
JURISDICTION	LEE'S SUMMIT, MO	
APPLICABLE CODE	2018 IBC 2018 IEBC 2012 IECC 2018 IMC NFPA 70 2017 NEC 2018 UPC 2018 IFGC 2016 ASME A17.1 2016 NFPA 72 2016 NFPA 13 2016 GA 60 2015 GA 216 UL CURRENT	
ADA STANDARDS	2010 ADA STANDARDS FOR ACCESSIBLE DESIGN	
OCCUPANCY CLASS	B (BUSINESS) OCC. IN A SEPARATED, MIXED-USE BUILDING	SECTION 303
CONSTRUCTION TYPE	II-B	SECTION 601
FIRE PROTECTION	AUTOMATIC SPRINKLER NO FIRE ALARM SYSTEM EXISTING FIRE EXTINGUISHER(S) REQUIRED	CHAPTER 9
ALLOWABLE HEIGHT AND AREA	55 FT / 23,000 (NS)	SECTION 504 & 506
FLOOR AREA (GROSS)	4,247 S.F.	TABLE 1004.5
OCCUPANT LOAD	44	TABLE 1004.5
EXITS REQUIRED	1	SECTION 1006
EXITS PROVIDED	3	
EXIT ACCESS TRAVEL DISTANCE	86'-7"	SECTION 1016

PLUMBING FIXTURE REQUIREMENT: IBC 2018 TABLE 2902.1

PLUMBING FIXTURE	MALE		FEMALE		TOTAL	
	REQUIRED	PROVIDED	REQUIRED	PROVIDED	REQUIRED	PROVIDED
WATER CLOSETS	2	3	2	3	4	6
LAVATORIES	1	2	1	2	2	4
DRINKING FOUNTAINS	-	-	-	-	1	0*
SERVICE SINKS	-	-	-	-	1	1**

*OWNER TO PROVIDE BOTTLED WATER AT ALL TIMES FOR EMPLOYEES & GUESTS.
**EXISTING MOP SINK TO REMAIN IN MECH 116.

CODE - OCCUPANCY CALCULATIONS

Room Name	Number	Area	Space Function (1004.1.2)	Load Factor	Occupancy Load Factor Net or Gross (1004.1.2)	# of People
-----------	--------	------	---------------------------	-------------	---	-------------

LEVEL 1


PRINT STATION	108A	19 SF	Business areas	150	gross	1
STORAGE	106	23 SF	Accessory storage areas, mechanical equipment rooms	300	gross	1
MECH.	116	35 SF	Accessory storage areas, mechanical equipment rooms	300	gross	1
STOR.	114	57 SF	Accessory storage areas, mechanical equipment rooms	300	gross	1
HUDDLE	<varies>	121 SF	Business areas	150	gross	2
I.T.	115	69 SF	Accessory storage areas, mechanical equipment rooms	300	gross	1
CIRCULATION	113A	90 SF	Circulation	0		0
WOMENS	117	120 SF	(none)			0
MENS	118	121 SF	(none)			0
BREAKROOM	113	161 SF	Assembly, without fixed, Unconcentrated (tables and chairs)	15	net	11
OFFICE	104	166 SF	Business areas	150	gross	2
OFFICE	103	174 SF	Business areas	150	gross	2
ENTRY	101	186 SF	Business areas	150	gross	2
OFFICE	105	202 SF	Business areas	150	gross	2
STORAGE	112	223 SF	Accessory storage areas, mechanical equipment rooms	300	gross	1
OFFICE	107	301 SF	Business areas	150	gross	3
COLLAB SPACE	109	326 SF	Business areas	150	gross	3
CONF.	102	389 SF	Business areas	150	gross	3
OPEN OFFICE	108	1,118 SF	Business areas	150	gross	8
Grand total: 20		3,899 SF	Business areas			44

EGRESS (COMMON PATH OF TRAVEL)

TYPE	DISTANCE
Egress Path A	89' - 3"
Egress Path B	86' - 7"


CODE SUMMARY

1" = 1'-0"




2 KEY PLAN

1" = 80'-0"



1 CODE PLAN

1/4" = 1'-0"



<div>SECTION 09 21 16 - GYPSUM BOARD ASSEMBLIES</div> <div>1. Provide completed assemblies complying with ASTM C840 and GA-216.</div> <div>2. Interior Partitions Indicated as Sound-Rated: STC as indicated calculated in accordance with ASTM E413, based on tests conducted in accordance with ASTM E90.</div> <div>3. Fire Rated Assemblies: Comply with applicable requirements of ICC IBC or GA-800 for the particular assembly. Provide construction equivalent to that listed for the particular assembly in the current UL Fire Resistance Directory.</div> <div>4. Manufacturers - Metal Framing, Connectors, and Accessories: ClarkDietrich, Scafo, or equal.</div> <div>5. Non-Loadbearing Framing System Components: ASTM C645; galvanized sheet steel, of size and properties necessary to comply with ASTM C754 for the spacing indicated, with maximum deflection of wall framing of L/240 at 5 psf.</div> <div>6. Studs: "C" shaped with flat or formed webs.</div> <div>7. Runners: U shaped, sized to match studs.</div> <div>8. Ceiling Channels: C shaped.</div> <div>9. Ceiling Hangers: Type and size as specified in ASTM C754 for spacing required.</div> <div>10. Partition Head to Structure Connections: Provide mechanical anchorage devices that accommodate deflection using slotted holes, screws and anti-friction bushings, preventing rotation of studs while maintaining structural performance of partition. Maintain lateral load resistance and vertical movement capacity required by applicable code, when evaluated in accordance with AISI North American Specification for the Design of Cold-Formed Steel Structural Members. Material: ASTM A653/A653M steel sheet, SS Grade 50/340, with G60/Z180 hot dipped galvanized coating. Provide components UL-listed for use in UL-listed fire-rated head of partition joint systems indicated on drawings. Deflection and Firestop Track: Provide mechanical anchorage devices as described above that accommodate deflection while maintaining the fire-rating of the wall assembly.</div> <div>11. Manufacturers - Gypsum-Based Board: National Gypsum Company, USG Corporation or equal.</div> <div>12. Gypsum Wallboard: Paper-faced gypsum panels as defined in ASTM C1396/C1396M, sizes to minimize joints in place, ends square cut. Application: Use for vertical surfaces and ceilings, unless otherwise indicated. At Assemblies Indicated with Fire-Rating: Use type required by indicated tested assembly; if no tested assembly is indicated, use Type X board, UL or WH listed. Thickness: Vertical Surfaces: 5/8 inch. Ceilings: 1/2 inch. Multi-Layer Assemblies: Thicknesses as indicated on drawings.</div> <div>13. Impact-Rated Wallboard: Tested to Level 3 soft-body and hard-body impact in accordance with ASTM C1629. Application: High-traffic areas indicated. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273. Thickness: 5/8 inch. Edges: Tapered.</div> <div>14. Backing Board For Wet Areas: Application: Surfaces behind tile in wet areas including tub and shower surrounds and shower ceilings. Glass-Mat-Faced Board: Coated glass mat water-resistant gypsum backing panel as defined in ASTM C1178.</div> <div>15. Backing Board For Non-Wet Areas: Water-resistant gypsum backing board as defined in ASTM C1396/C1396M; sizes to minimum joints in place, ends square cut. Application: Vertical surfaces behind thinset tile, except in wet areas. Type: Regular and Type X, in locations indicated. Type X Thickness: 5/8 inch. Regular Board Thickness: 5/8 inch. Edges: Tapered.</div> <div>16. Ceiling Board: Special sag-resistant gypsum ceiling board as defined in ASTM C1396/C1396M; sizes to minimize joints in place, ends square cut. Application: Ceilings, unless otherwise indicated. Thickness: 1/2 inch. Edges: Tapered.</div> <div>17. Acoustical Sound Dampening Wall and Ceiling Board: Two layers of heavy paper faced, high density gypsum board separated by a viscoelastic polymer layer and capable of achieving STC rating of 50 or more in typical stud wall assemblies as calculated in accordance with ASTM E413 and when tested in accordance with ASTM E90. Thickness: 1/2 inch. Long Mold Resistance: Score of 10, when tested in accordance with ASTM D3273. Thickness: ___ inch.</div> <div>18. Acoustic Insulation: ASTM C685; preformed glass fiber, friction fit type, unfaced. Thickness: ___ inch.</div> <div>19. Acoustic Sealant: Non-hardening, non-skinning, for use in conjunction with gypsum board.</div> <div>20. Joint Materials: ASTM C475 and as recommended by gypsum board manufacturer for project conditions.</div> <div>21. High Build Drywall Surface: Vinyl acrylic latex-based primer for spray application, designed to take the place of skim coating and separate paint primer in achieving Level 5 finish.</div> <div>22. Screws for Attachment to Steel Members Less Than 0.03 inch In Thickness, to Wood Members, and to Gypsum Board: ASTM C1002; self-piercing tapping type.</div> <div>23. Screws for Attachment to Steel Members From 0.033 to 0.112 inch in Thickness: ASTM C954; steel drill screws for application of gypsum board to loadbearing steel studs.</div> <div>24. Metal Framing: Install in accordance with ASTM C754 and manufacturer's instructions.</div> <div>25. Suspended Ceilings and Soffits: Space framing and furring members as indicated.</div> <div>26. Studs: Space studs as indicated. Extend partition framing to structure where indicated and to ceiling in other locations.</div> <div>27. Partitions Terminating at Ceiling: Attach ceiling runner securely to ceiling track in accordance with manufacturer's instructions.</div> <div>28. Partitions Terminating at Structure: Attach top runner to structure, maintain clearance between top of studs and structure, and connect studs to track using specified mechanical devices in accordance with manufacturer's instructions; verify free movement of top of stud connections; do not leave studs unattached to track.</div> <div>29. Openings: Reinforce openings as required for weight of doors or operable panels, using not less than double studs at jambs.</div> <div>30. Acoustic Insulation: Place tightly within spaces, around cut openings, behind and around electrical and mechanical items within partitions, and tight to items passing through partitions.</div> <div>31. Acoustic Sealant: Install in accordance with manufacturer's instructions. Place one bead continuously on substrate before installation of perimeter framing members. Place continuous bead at perimeter of each layer of gypsum board. In non-fire-rated construction, seal around all penetrations by conduit, pipe, ducts, and rough-in boxes.</div> <div>32. Board Installation: Comply with ASTM C840, GA-216, and manufacturer's instructions. Install to minimize butt end joints, especially in highly visible locations. Install gypsum board parallel to framing, with ends and edges occurring over firm bearing.</div> <div>33. Fire-Rated Construction: Install gypsum board in strict compliance with requirements of assembly listing.</div> <div>34. Installation on Metal Framing: Use screws for attachment of all gypsum board.</div> <div>35. Curved Surfaces: Apply gypsum board to curved substrates in accordance with GA-226.</div> <div>36. Moisture Protection: Treat cut edges and holes in moisture resistant gypsum board with sealant.</div> <div>37. Control Joints: Place control joints not more than 30 feet apart on walls and ceilings over 50 feet long, unless otherwise indicated on Drawings.</div> <div>38. Corner Beads: Install at external corners, using longest practical lengths.</div> <div>39. Finish gypsum board in accordance with levels defined in ASTM C840.</div> <div>40. Level 4: Walls and ceilings to receive paint finish or wall coverings, unless otherwise indicated.</div> <div>41. Level 5: Walls and ceilings to receive semi-gloss or gloss paint finish and other areas specifically indicated.</div> <div>42. Level 2: In utility areas, behind cabinetry, and on backing board to receive tile finish.</div> <div>43. Level 1: Fire rated wall areas above finished ceilings, whether or not accessible in the completed construction.</div> <div>44. Level 0: Temporary partitions and surfaces indicated to be finished in later stage of project.</div> <div>45. Tape, fill, and sand exposed joints, edges, and corners to produce smooth surface ready to receive finishes. Feather coats of joint compound so that camber is maximum 1/32 inch.</div> <div>46. Where Level 5 finish is indicated, spray apply high build drywall surface over entire surface after joints have been properly treated; achieve a flat and tool mark-free finish.</div> <div>47. Maximum Variation of Finished Gypsum Board Surface from True Flatness: 1/8 inch in 10 feet in any direction.</div> <div>SECTION 09 30 00 - TILING</div> <div>1. Standard Grout. Any type specified in ANSI A118.6 or A118.7.</div> <div>2. Verify that surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive tile.</div> <div>3. Verify that concrete sub-floor surfaces are ready for tile installation by testing for moisture emission rate and alkalinity; obtain instructions if test results are not within limits recommended by tile manufacturer and setting materials manufacturer.</div> <div>4. Protect surrounding work from damage.</div> <div>5. Seal substrate surface cracks with filler. Level existing substrate surfaces to acceptable flatness tolerances.</div> <div>6. Prepare substrate surfaces for adhesive installation in accordance with adhesive manufacturer's instructions.</div> <div>7. Install tile and thresholds and grout in accordance with applicable requirements of ANSI A108.1 through A108.13, manufacturer's instructions, and The Tile Council of North America Handbook recommendations.</div> <div>8. Lay tile to establish grid pattern through openings unless otherwise indicated.</div> <div>9. Cut and fit tile to penetrations through tile, leaving sealant joint space. Form corners and bases neatly. Align floor joints.</div> <div>10. Place tile joints uniform in width, subject to variance in tolerance allowed in tile size. Make joints watertight, without voids, cracks, excess mortar, or excess grout.</div> <div>11. Install ceramic accessories rigidly in prepared openings.</div> <div>12. Install non-ceramic trim in accordance with manufacturer's instructions.</div> <div>13. Install thresholds where indicated.</div> <div>14. Sound tile after setting. Replace hollow sounding units.</div> <div>15. Keep expansion joints free of adhesive or grout. Apply sealant to joints.</div> <div>16. Allow tile to set for a minimum of 48 hours prior to grouting.</div> <div>17. Grout tile joints. Use standard grout unless otherwise indicated.</div> <div>18. Apply sealant to junction of tile and dissimilar materials and junction of dissimilar planes.</div> <div>19. Over interior concrete substrates, install in accordance with The Tile Council of North America Handbook Method F113, dry-set or latex-Portland cement bond coat, with standard grout, unless otherwise indicated.</div> <div>20. At tiled shower receptors install in accordance with The Tile Council of North America Handbook Method B415, mortar bed floor, and W244, thin-set over cementitious backer unit walls.</div> <div>21. Over gypsum wallboard on wood or metal studs install in accordance with The Tile Council of North America Handbook Method W243, thin-set with dry-set or latex-Portland cement bond coat, unless otherwise indicated.</div> <div>22. Do not permit traffic over finished floor surface for 4 days after installation.</div> <div>SECTION 09 51 00 - ACOUSTICAL CEILINGS</div> <div>1. Maintain uniform temperature of minimum 60 degrees F, and maximum humidity of 40 percent prior to, during, and after acoustical unit installation.</div> <div>2. Acoustical Units - General: ASTM E1264, Class A.</div> <div>3. Units for Installation in Fire-Rated Suspension System: Listed and classified for the fire-resistive assembly the suspension system is a part of.</div> <div>4. Suspension System Manufacturers: Same as for acoustical units indicated on Drawings.</div> <div>5. Suspension Systems - General: ASTM C635; die cut and interlocking components, with stabilizer bars, clips, splices, perimeter moldings, and hold down clips as required.</div> <div>6. Support Channels and Hangers: Galvanized steel; size and type to suit application, seismic requirements, and ceiling system flatness requirement specified.</div> <div>7. Perimeter Moldings: Same material and finish as grid.</div> <div>8. Install suspension system in accordance with ASTM C636/C636M, ASTM E580/E580M, and manufacturer's instructions and as supplemented in this section.</div> <div>9. Rigidly secure system, including integral mechanical and electrical components, for maximum deflection of 1:360.</div> <div>10. Install after major above-ceiling work is complete. Coordinate the location of hangers with other work.</div> <div>SECTION 09 51 00 - ACOUSTICAL CEILINGS (CONTINUED)</div> <div>11. Hang suspension system independent of walls, columns, ducts, pipes and conduit. Where carrying members are spliced, avoid visible displacement of face plane of adjacent members.</div> <div>12. Where ducts or other equipment prevent the regular spacing of hangers, reinforce the nearest affected hangers and related carrying channels to span the extra distance.</div> <div>13. Do not support components on main runners or cross runners if weight causes total dead load to exceed deflection capability.</div> <div>14. Support fixture loads using supplementary hangers located within 6 inches of each corner, or support components independently.</div> <div>15. Do not eccentrically load system or induce rotation of runners.</div> <div>16. Perimeter Molding: Install at intersection of ceiling and vertical surfaces and at junctions with other interruptions.</div> <div>17. Use longest practical lengths.</div> <div>18. Overlap and rivet corners.</div> <div>19. Install acoustical units in accordance with manufacturer's instructions.</div> <div>20. Fit acoustical units in place, free from damaged edges or other defects detrimental to appearance and function.</div> <div>21. Fit border trim neatly against abutting surfaces.</div> <div>22. Install units after above-ceiling work is complete.</div> <div>23. Install acoustical units level, in uniform plane, and free from twist, warp, and dents.</div> <div>24. Cutting Acoustical Units: Make field cut edges of same profile as factory edges.</div> <div>25. Lay acoustical insulation for a distance of 48 inches either side of acoustical partitions as indicated.</div> <div>26. Maximum Variation from Flat and Level Surface: 1/8 inch in 10 feet.</div> <div>27. Maximum Variation from Plumb of Grid Members Caused by Eccentric Loads: 2 degrees.</div> <div>RESILIENT BASE</div> <div>1. Fit joints tightly and make vertical. Maintain minimum dimension of 18 inches between joints.</div> <div>2. Install baseboard on solid backing, and floor surfaces.</div> <div>3. Scribe and fit to door frames and other interruptions.</div> <div>SECTION 09 68 00 - CARPETING</div> <div>1. Store materials in area of installation for minimum period of 24 hours prior to installation.</div> <div>2. Maintain minimum 70 degrees F ambient temperature prior to, during and 24 hours after installation.</div> <div>3. Ventilate installation area during installation and for 72 hours after installation.</div> <div>4. Sub-Floor Filler: Type recommended by carpet manufacturer.</div> <div>5. Adhesives - General: Compatible with materials being adhered; maximum VOC content of 50 g/L; CRI Green Label certified.</div> <div>6. Seam Adhesive: Recommended by manufacturer.</div> <div>7. Contact Adhesive: Recommended by carpet manufacturer; releasable type.</div> <div>8. Verify that surfaces are smooth and flat within the tolerances specified for that type of work and are ready to receive carpet.</div> <div>9. Verify that sub-floor surfaces are dust-free and free of substances that could impair bonding of adhesives to sub floor surfaces.</div> <div>10. Cementitious Sub-floor Surfaces: Verify that substrates are dry enough and ready for resilient flooring installation by testing for moisture and pH. Test in accordance with ASTM F710.</div> <div>11. Obtain instructions if test results are not within limits recommended by resilient flooring manufacturer and adhesive materials manufacturer.</div> <div>12. Prepare floor substrates as recommended by flooring and adhesive manufacturers.</div> <div>13. Starting installation constitutes acceptance of sub-floor conditions.</div> <div>14. Install carpet in accordance with manufacturer's instructions and CRI Carpet Installation Standard.</div> <div>15. Verify carpet match before cutting to ensure minimal variation between dye lots.</div> <div>16. Lay out carpet and locate seams in accordance with shop drawings:</div> <div>17. Locate seams in area of least traffic, out of areas of pivoting traffic, and parallel to main traffic.</div> <div>18. Do not locate seams perpendicular through door openings.</div> <div>19. Align run of pile in same direction as anticipated traffic and in same direction on adjacent pieces.</div> <div>20. Locate changes of color or pattern between rooms under door centerline.</div> <div>21. Provide monolithic color, pattern, and texture match within any one area.</div> <div>22. Install carpet tight and flat on subfloor, well fastened at edges, with a uniform appearance.</div> <div>23. Trim carpet neatly at walls and around all interruptions.</div> <div>24. Remove excess adhesive from floor and wall surfaces without damage.</div> <div>25. Clean and vacuum carpet surfaces.</div> <div>SECTION 09 72 00 - WALL COVERINGS</div> <div>1. Extra Materials: Deliver to Owner full-width rolls of wall covering equal to 5 percent of amount of each type installed, packaged with protective covering for storage.</div> <div>2. Adhesive: Type recommended by wall covering manufacturer to suit application to substrate.</div> <div>3. Substrate Filler, Primer and Sealer: As recommended by adhesive and wall covering manufacturers; compatible with substrate.</div> <div>4. Verify that substrate surfaces are prime painted and ready to receive work, and conform to requirements of the wall covering manufacturer.</div> <div>5. Measure moisture content of surfaces using an electronic moisture meter. Do not apply wall coverings if moisture content of substrate exceeds level recommended by wall covering manufacturer.</div> <div>6. Treat areas as necessary to ensure no pigment bleeding through wall covering.</div> <div>7. Apply adhesive and wall covering in accordance with manufacturer's instructions.</div> <div>8. Apply wall covering smooth, without wrinkles, gaps or overlaps. Eliminate air pockets and ensure full bond to substrate surface. Butt edges tightly.</div> <div>9. Install seams vertical and plumb. Horizontal seams are not acceptable.</div> <div>10. Do not seam within 2 inches of internal corners or within 6 inches of external corners.</div> <div>11. Where wall covering backs into cavels, or on metal wallboard or plaster stops, apply with contact adhesive within 6 inches of wall covering termination. Ensure full contact bond.</div> <div>12. Remove excess adhesive at finished seams, perimeter edges, and adjacent surfaces using cleaning methods recommended by wall covering manufacturer.</div> <div>13. Clean wall coverings of excess adhesive, dust, dirt, and other contaminants.</div> <div>SECTION 09 80 00 - ACOUSTIC TREATMENT</div> <div>1. Principal Products:</div> <div>A. Acoustic panel treatment - walls</div> <div>B. Acoustic baffle treatment - ceilings</div> <div>2. Submit Product Data: For manufacturer's product lines and accessories. Include construction details, mounting, material descriptions, dimensions of individual components and profiles, and finishes.</div> <div>3. Shop Drawings: Include mounting devices and details; details at panel head, base, joints, and corners; and details at ceiling, floor base, and wall intersections. Indicate panel edge and core materials. Include plans and elevations showing panel sizes and direction of fabric weave and pattern matching.</div> <div>4. Provide Maintenance Data: For sound-absorbing wall units to include in maintenance manuals. Include fabric manufacturers' written cleaning and repair recommendations.</div> <div>5. Provide Flame spread/smoke developed index with Class A fire rated certification when tested in accordance with ASTM E84.</div> <div>6. Installer's Qualifications: A firm experienced in producing acoustic treatment similar to that indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.</div> <div>7. Comply with manufacturers' written instructions for minimum and maximum temperature and humidity requirements for shipment, storage, and handling.</div> <div>8. Deliver materials in unopened bundles.</div> <div>9. Store materials in cool, dry, well ventilated area out of direct sunlight and away from heat sources.</div> <div>10. Do not allow water to come into direct contact with material during storage.</div> <div>11. Do not store materials longer than 6 months.</div> <div>12. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer.</div> <div>13. Verify field measurements before fabrication.</div> <div>14. Obtain acoustic treatment system from single source from single manufacturer.</div> <div>15. General Requirements for Acoustic Treatment: Provide systems that comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."</div> <div>16. Fire-Test-Response Characteristics: Provide fabric systems meeting the following requirements as determined by testing identical products by UL 723, UBC, or another testing and inspecting agency acceptable to authorities having jurisdiction.</div> <div>A. Surface-Burning Characteristics: Comply with ASTM E 84; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.</div> <div>1. Flame-Spread Index: 25or less.</div> <div>b. Smoke-Developed Index: 450 or less.</div> <div>17. Fire Growth Contribution: Comply with acceptance criteria of local code and authorities having jurisdiction when tested according to NFPA 285 or NFPA 286.</div> <div>17. Provide equivalent size, color and pattern as product listed on drawings.</div> <div>18. Provide manufacturer's standard core material.</div> <div>19. Install acoustic wall panels using manufacturer's recommended installation products and methods.</div> <div>20. Install acoustic ceiling panels behind manufacturer's standard aircraft wire secured to substrate.</div> <div>21. Edge Construction: Manufacturer's standard frame, cross runner, frame connectors and end caps. Color to match panels.</div> <div>22. Acoustical Performance: Sound absorption NRC of 0.90 according to ASTM C 423 for Type A mounting according to ASTM E 795.</div> <div>23. Examine fabric, fabricated units, substrates, areas, and conditions, for compliance with requirements, installation tolerances, and other conditions affecting performance of sound-absorbing wall units.</div> <div>24. Proceed with installation only after unsatisfactory conditions have been corrected.</div> <div>25. Comply with manufacturer's written instructions for installation of acoustic treatment units using type of mounting devices indicated. Mount units securely to supporting substrate.</div> <div>26. Unroll acoustic panels sheets and allow 1 to stabilize before cutting and fitting.</div> <div>27. Align and level fabric pattern and grain among adjacent units.</div> <div>28. Install wall units in locations indicated with vertical surfaces and edges plumb, top edges level and in alignment with other units, faces flush, and scribed to fit adjoining work accurately at borders and at penetrations.</div> <div>29. Install ceiling units in locations indicated with edges in alignment with walls and other units, faces flush, and scribed to fit adjoining work accurately at borders and at penetrations.</div> <div>30. Variation from Alignment with Surfaces: Plus or minus 1/16 inch.</div> <div>31. Variation from Level or Slope: Plus or minus 1/16 inch.</div> <div>32. Variation of Panel Joints from Hairline: Not more than 1/16 inch wide.</div> <div>33. Vacuum clean panels on completion of installation to remove dust and other foreign materials according to manufacturer's written instructions.</div> <div>34. Remove spills immediately using clean damp cloth or with soap and water.</div> <div>SECTION 09 90 00 - PAINTING AND COATING</div> <div>1. Scope: Finish all interior and exterior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated.</div> <div>2. Mechanical and Electrical: In finished areas, paint all insulated and exposed pipes, conduit, boxes, insulated and exposed ducts, hangers, brackets, collars and supports, mechanical equipment, and electrical equipment, unless otherwise indicated on Drawings.</div> <div>3. Do Not Paint or Finish the Following Items: Items fully factory-finished unless specifically so indicated; materials and products having factory-applied primers are not considered factory finished. Items indicated to receive other finishes. Items indicated to remain unfinished. Fire rating labels, equipment serial number and capacity labels, and operating parts of equipment. Floors, unless specifically so indicated. Ceramic and other tiles. Glass. Acoustical materials, unless specifically so indicated. Concealed pipes, ducts, and conduits.</div> <div>4. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.</div> <div>5. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.</div> <div>6. Paint Materials: Store at minimum ambient temperature of 45 degrees F and a maximum of 90 degrees F, in ventilated area, and as required by manufacturer's instructions.</div> <div>7. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.</div> <div>8. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.</div> <div>9. Provide lighting level of 80 ft candles measured mid-height at substrate surface.</div> <div>10. Provide all paint and coating products used in any individual system from the same manufacturer; no exceptions.</div> <div>11. Provide all paint and coating products from the same manufacturer to the greatest extent possible.</div> <div>12. Paints and Coatings: Ready mixed, unless intended to be a field-catalyzed coating.</div> <div>13. Provide paints and coatings of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.</div> <div>14. Supply each coating material in quantity required to complete entire project's work from a single production run.</div> <div>15. Do not reduce, thin, or dilute coatings or add materials to coatings unless such procedure is specifically described in manufacturer's product instructions.</div> <div>16. Primers: Where the manufacturer offers options on primers for a particular substrate, use primer categorized as "best" by the manufacturer.</div> <div>17. Volatile Organic Compound (VOC) Content:</div> <div>18. Provide coatings that comply with the most stringent requirements specified in the following: 40 CFR 59, Subpart D-- National Volatile Organic Compound Emission Standards for Architectural Coatings. Architectural coatings VOC limits of State in which the project is located.</div> <div>19. Colors: As indicated on Drawings. In finished areas, finish pipes, ducts, conduit, and equipment the same color as the wall/ceiling they are mounted on/under.</div> <div>20. Paint for Wood, Opaque: One coat of latex primer sealer. Two coats of latex enamel.</div> <div>21. Paint for Wood, Transparent, Varnish, No Stain: One coat sealer.</div> <div>22. Paint for Wood, Transparent, Varnish, Stain: Filler coat (for open grained wood only). One coat of stain. One coat sealer. One coat of varnish.</div> <div>23. Paint for Concrete/Masonry, Opaque: One coat of block filler. Two coats of alkyd enamel.</div> <div>24. Paint for Ferrous Metals, Unprimed: One coat of latex primer. Two coats of latex enamel.</div> <div>25. Paint for Ferrous Metals, Primed: Touch-up with latex primer. Two coats of latex enamel.</div> <div>26. Paint for Gypsum Board/Plaster: One coat of latex primer. Two coats of latex enamel.</div> <div>27. Accessory Materials: Provide all primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials required to achieve the finishes specified whether specifically indicated or not; commercial quality.</div> <div>28. Patching Material: Latex filler.</div> <div>29. Fastener Head Cover Material: Latex filler.</div> <div>30. Clean surfaces thoroughly and correct defects prior to coating application.</div> <div>31. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.</div> <div>32. Remove or mask surface appearances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces or finishing.</div> <div>33. Seal surfaces that might cause bleed through or staining of topcoat.</div> <div>34. Remove mildew from impervious sur faces by scrubbing with solution of tetra-sodium phosphate and bleach. Rinse with clean water and allow surface to dry.</div> <div>35. Concrete and Unit Masonry Surfaces to be Painted: Remove dirt, loose mortar, scale, salt or alkali powder, and other foreign matter. Remove oil and grease with a solution of tri-sodium phosphate; rinse well and allow to dry. Remove stains caused by weathering of corroding metals with a solution of sodium metasilicate after thoroughly wetting with water. Allow to dry.</div> <div>36. Gypsum Board Surfaces to be Painted: Fill minor defects with filler compound. Spot prime defects after repair.</div> <div>37. Galvanized Surfaces to be Painted: Remove surface contamination and oils and wash with solvent. Apply coat of etching primer.</div> <div>38. Corroded Steel and Iron Surfaces to be Painted: Prepare using at least SSPC-PC 2 (hand tool cleaning) or SSPC-SP 3 (power tool cleaning), followed by SSPC-SP 1 (solvent cleaning).</div> <div>39. Unrecorded Uncoated Steel and Iron Surfaces to be Painted: Remove grease, mill scale, weld splatter, dirt, and rust. Where heavy coatings of scale are evident, remove by hand or power tool wire brushing or sandblasting; clean by washing with solvent. Apply a treatment of phosphoric acid solution, ensuring weld joints, bolts, and nuts are similarly cleaned. Prime paint entire surface; spot prime after repairs.</div> <div>40. Shop-Primed Steel Surfaces to be Finish Painted: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Clean surfaces with solvent. Prime bare steel surfaces. Re-prime entire shop-primed item.</div> <div>41. Interior Wood Surfaces to Receive Opaque Finish: Wipe off dust and grit prior to priming. Seal knots, pitch streaks, and sappy sections with sealer. Fill nail holes and cracks after primer has dried; sand between coats. Back prime concealed surfaces before installation.</div> <div>42. Interior Wood Surfaces to Receive Transparent Finish: Wipe off dust and grit prior to sealing; seal knots, pitch streaks, and sappy sections with sealer. Fill nail holes and cracks after sealer has dried; sand lightly between coats. Prime concealed surfaces with gloss varnish reduced 25 percent with thinner.</div> <div>43. Wood Doors to be Field-Finished: Seal wood door top and bottom edge surfaces with clear sealer.</div> <div>44. Remove unfinished louvers, grilles, covers, and access panels on mechanical and electrical components and paint separately.</div> <div>45. Apply products in accordance with manufacturer's instructions.</div> <div>46. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.</div> <div>47. Apply each coat to uniform appearance.</div> <div>48. Sand wood and metal surfaces lightly between coats to achieve required finish.</div> <div>49. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.</div> <div>50. Wood to Receive Transparent Finishes: Tint fillers to match wood. Work fillers into the grain before set. Wipe excess from surface.</div> <div>51. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.</div> <div>SECTION 10 44 00 - FIRE PROTECTION SPECIALTIES</div> <div>1. Fire Extinguishers, Fire Extinguisher Cabinets and Accessories: Ansul, Inc., Pyro-Chem, or equal.</div> <div>2. Fire Extinguishers - General: Comply with product requirements of NFPA 10 and applicable codes, whichever is more stringent. Provide extinguishers labeled by UL for the purpose specified and indicated.</div> <div>3. Extinguisher Brackets: Formed steel, galvanized and enamel finished.</div> <div>4. Install in accordance with manufacturer's instructions.</div> <div>5. Install cabinets plumb and level in wall openings, 54 inches from finished floor to inside bottom of cabinet.</div> <div>6. Secure rigidly in place.</div> <div>7. Place extinguishers and accessories in cabinets and on wall brackets.</div> <div>SECTION 11 31 00 - RESIDENTIAL APPLIANCES</div> <div>1. Verify utility rough-ins are present and correctly located.</div> <div>2. Install in accordance with manufacturer's instructions.</div> <div>3. Anchor built-in equipment in place.</div> <div>4. Adjust operating equipment to efficient operation.</div> <div>5. Remove packing materials from equipment.</div> <div>6. Wash and clean equipment.</div> <div>SECTION 12 36 00 - COUNTERTOPS</div> <div>1. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.</div> <div>2. Quality Standard: Premium Grade, in accordance with AIA/AIA/MAC/MI Architectural Woodwork Standards.</div> <div>3. Medium Density Fiberboard for Supporting Substrate: ANSI A208.2.</div> <div>4. Adhesives: Chemical resistant waterproof adhesive as recommended by manufacturer of materials being joined.</div> <div>5. Fabricate tops and splashes in the largest sections practicable, with top surface of joints flush.</div> <div>6. Join lengths of tops using best method recommended by manufacturer.</div> <div>7. Prepare all cutouts accurately to size; replace tops having improperly dimensioned or unnecessary cutouts or fixture holes.</div> <div>8. Solid Surfacing: Fabricate tops up to 144 inches long in one piece; join pieces with adhesive sealant in accordance with manufacturer's recommendations and instructions.</div> <div>9. Wall-Mounted Counters: Provide skirts, aprons, brackets, and braces as indicated on drawings.</div> <div>10. Do not begin installation until substrate has been properly prepared.</div> <div>11. Verify that wall surfaces have been finished and mechanical and electrical services and outlets are installed in proper locations.</div> <div>12. Clean surfaces thoroughly prior to installation.</div> <div>13. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.</div> <div>14. Securely attach countertops to cabinets using concealed fasteners. Make flat surfaces level; shim where required.</div> <div>15. Attach plastic laminate countertops using screws with minimum penetration into substrate grade of 5/8 inch.</div> <div>16. Seal joint between back/end splashes and vertical surfaces.</div> <div>17. Variation From Horizontal: 1/8 inch in 10 feet, maximum.</div> <div>18. Offset From Wall, Countertops: 1/8 inch maximum; 1/16 inch minimum.</div> <div>19. Field Joints: 1/8 inch wide, maximum.</div> <div>20. Clean countertops surfaces thoroughly.</div> <div>21. Protect installed products until completion of project.</div> <div>22. Touch-up, repair or replace damaged products before Substantial Completion.</div> <div>SECTION 12 24 13 - ROLLER WINDOW SHADES</div> <div>1. Provide product as indicated on drawings or approved equal by Architect.</div> <div>2. Product shall have a manual operation.</div> <div>3. Mounting: Inside mount and top mount.</div> <div>4. Configuration: Single Solar Shadecloth</div> <div>5. Solar Shadecloth: 3% Openness. Color as indicated on drawings.</div> <div>6. Hardware Finish: To be selected by architect from manufacturer's full range.</div> <div>7. Install window treatment in accordance with manufacturer's instructions.</div> <div>8. Maximum Variation of Gap at Window Opening Perimeter: 1/4 inch.</div> <div>9. Maximum Offset From Level: 1/8 inch.</div> <div>10. Adjust window treatment for smooth operation.</div> <div>11. Clean shade and valance surfaces just prior to occupancy.</div>	<div><div><div><div><div></div><div>HIVE</div></div></div><div><div><div><div></div><div>PERFECT PROMOTIONS</div></div><div><div><div><div></div><div>1469 SW Market Street</div><div>LEE'S SUMMIT, MO 64081</div></div><div><div><div><div></div><div>HIVE DESIGN COLLABORATIVE, INC.</div><div>1617 WALNUT STREET, KANSAS CITY, MO 64108</div><div>816.581.6363</div></div></div></div></div><div><div><div><div></div><div>COPYRIGHT © 2022</div><div>HIVE DESIGN COLLABORATIVE, INC.</div></div><div><div><div><div></div><div>seal/signature</div></div><div><div><div><div></div><div>06.13.22</div></div><div><div><div><div></div><div>project number</div><div>2022-018</div></div><div><div><div><div></div><div>date</div><div>05.25.2022</div></div><div><div><div><div></div><div>issued for</div><div>PERMIT</div></div><div><div><div><div></div><div>rev</div><div>date</div><div>description</div></div></div></div></div><div><div><div><div></div><div>sheet number</div></div><div><div><div><div></div><div>G501</div></div></div></div></div></div></div></div></div></div></div></div></div></div></div></div></div></div></div></div></div></div>
--	---



DEMOLITION KEY NOTES:

- 1 DEMO EXISTING NON-BEARING WALL. NOTIFY ARCHITECT OF ANY DISCREPANCIES.
- 2 REMOVE EXISTING DOOR AND ASSOCIATED HARDWARE. SALVAGE & PROTECT FOR REINSTALLATION. REFER TO FLOORPLAN FOR NEW LOCATION OF EXISTING DOOR.
- 3 DEMO EXISTING CARPET FLOORING. PREP CONCRETE TO BE EXPOSED AND SEALED.
- 4 DEMO EXISTING PLUMBING FIXTURES AND ACCESSORIES. CAP PLUMBING AND REPAIR FLOORING AS REQUIRED.
- 5 REPAIR FLOORING AS REQUIRED AFTER DEMOLITION OF WALL.
- 6 REMOVE EXISTING CAN LIGHT FIXTURES IN FUTURE OPEN OFFICE AREA. SALVAGE & PROTECT FOR REINSTALLATION.
- 7 CAP EXISTING PLUMBING IN WALL, RE: MEP. SEE GENERAL DEMO NOTE 10.
- 8 CAP EXISTING PLUMBING IN FLOOR OR ABOVE CEILING, RE: MEP. SEE GENERAL DEMO NOTE 10.
- 9 DEMO EXISTING FRP ON WALLS. PATCH AND REPAIR WALLS AS NECESSARY TO RECEIVE NEW FINISH.
- 10 REMOVE, SALVAGE AND PROTECT EXISTING EXIT LIGHT OVER DOOR. COORDINATE STORAGE LOCATION WITH PROPERTY MANAGER. PATCH AND REPAIR WALL AS NECESSARY TO RECEIVE NEW FINISH.
- 11 PATCH AND REPAIR WALL AS NECESSARY TO RECEIVE NEW FINISH.
- 12 REMOVE WALL AS NECESSARY TO ACCOMMODATE NEW DOOR.

GENERAL DEMOLITION NOTES:

1. REFER TO SHEET G001 FOR ADDITIONAL GENERAL NOTES THAT ARE APPLICABLE.
2. CONTRACTOR TO VISIT PROJECT SITE AND BUILDING PRIOR TO BID.
3. CONTRACTOR TO PROTECT EXISTING FINISHES ADJACENT TO DEMOLITION WORK.
4. CONTRACTOR TO PATCH AND REPAIR ALL WORK, ESPECIALLY WORK ADJACENT TO EXISTING AREAS, AS REQUIRED.
5. CONTRACTOR TO REPAIR ANY AREAS DAMAGED DURING DEMOLITION.
6. CONTRACTOR TO COORDINATE DEMOLITION OPENINGS WITH NEW FLOOR PLANS.
7. PROTECT ALL ITEMS TO REMAIN (WALLS, PLUMBING FIXTURES, PIPING, HVAC UNITS, COLUMNS, ETC).
8. BUILDING TO REMAIN SECURE DURING DEMOLITION AND CONSTRUCTION.
9. REMOVE EXISTING GYP BOARD AS NECESSARY TO PROVIDE NEW BLOCKING IN EXISTING WALLS FOR NEW CASEWORK AND EQUIPMENT. REPAIR ANY PUNCTURES OR TEARS TO THE VAPOR BARRIER AT THE EXTERIOR WALLS.
10. REMOVE AND CAP ALL WATER, WASTE, GAS, ELECTRICAL CONDUIT, AND ANY OTHER LINES NO LONGER TO BE USED TO 1" BELOW TOP OF CONCRETE SLAB. TERMINATE ANY ROOF PENETRATION LINES 6" BELOW ROOF DECK. DO NOT REMOVE ANY EXISTING OR CREATE ANY NEW ROOF PENETRATIONS AS PART OF THE DEMOLITION WORK.

PERFECT PROMOTIONS

1469 SW Market Street
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



06.13.22

project number 2022-018

date 05.25.2022


issued for PERMIT

rev	date	description
-----	------	-------------

DEMOLITION
PLAN


sheet number

AD100



1 DEMO PLAN

1/4" = 1'-0"



NOTES

1/4" = 1'-0"



PERFECT PROMOTIONS

1469 SW Market Street
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



06.13.22

project number 2022-018

date 05.25.2022

issued for PERMIT

rev	date	description
1	06/08/22	CITY COMMENTS

FLOOR PLAN

sheet number



A100

FLOOR PLAN KEY NOTES:

- 1 ALIGN FACE OF NEW GYP WALL WITH FACE OF EXISTING GYP WALL.
- 2 ALIGN NEW GYP WALL WITH EXISTING WALL. WIDTH OF NEW WALL SHALL MATCH WIDTH OF EXISTING WALL.
- 3 ALIGN FACES OF NEW GYP WALLS.
- 4 LOCK DOOR & REMOVE EXISTING EXTERIOR HARDWARE. TURN OVER HARDWARE TO BUILDING OWNER.
- 5 CENTER NEW WALL ON EXISTING MULLION. TRIM EXPOSED WALL EDGE WITH BRAKE METAL WRAP TO MATCH EXIST STOREFRONT.
- 6 THE EXISTING DEMISING WALL SHALL EXTEND TO THE DECK, CONTRACTOR TO VERIFY.
- 7 EXISTING MOP SINK TO REMAIN.

GENERAL NOTES - FLOOR PLANS:

1. DIMENSIONS SHOWN ON THE FLOOR PLAN ARE TO THE FACE OF GYP. BOARD WALL (FOG), FACE OF MASONRY (FOM), FACE OF CONCRETE WALLS (FOC), AND COLUMN GRID LINES, UNLESS NOTED OR SHOWN OTHERWISE.
2. DOOR OPENINGS NOT LOCATED BY DIMENSION SHALL BE CENTERED IN WALL SHOWN OR LOCATED 4 INCHES FROM FINISH WALL TO HINGE SIDE OF THE DOOR. ALWAYS ALLOWING A MINIMUM OF 18" FROM THE PULL SIDE (STRIKE SIDE) OF THE DOOR TO THE INTERSECTING WALL, OR OTHER PROTRUDING OBJECTS.
3. ALL CLOSETS AND ALCOVES WITHOUT A SPACE IDENTIFICATION NUMBER SHALL HAVE THE SAME FINISHES AS THE ADJOINING SPACES.
4. ALL PUBLIC SPACES: THE WALLS WILL BE FINISHED WITH 5/8" GYP. BD. TO A LEVEL 4 FINISH AND PAINTED, UNLESS NOTED OR SPECIFIED OTHERWISE.
5. RE: FINISH LEGEND, FINISH SCHEDULE AND SPECIFICATIONS FOR DOOR AND DOOR FRAME FINISHES.
6. ALL GLAZING IN CODE SPECIFIED "HAZARDOUS LOCATIONS" (i.e. DOORS, SIDE LITES, ETC.) SHALL COMPLY WITH THE SAFETY GLAZING REQUIREMENTS AS OUTLINED IN SECTIONS 2406 AND 2406.3 OF THE IBC.



1 FLOOR PLAN

NOTES

1/4" = 1'-0"

1/4" = 1'-0"



PERFECT PROMOTIONS

1469 SW Market Street
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



06.13.22

project number 2022-018

date 05.25.2022

issued for PERMIT

rev date description

REFLECTED
CEILING PLAN

sheet number

A101

REFLECTED CEILING PLAN SYMBOLS:

- 9'-0" CEILING HEIGHT
- EXISTING SUSP. CEILING SYSTEM
- NEW SUSP. CEILING SYSTEM
- EXISTING 2X4 LIGHT FIXTURE
- NEW 2X4 LIGHT FIXTURE, RE: MEP
- EXISTING RETURN/ SUPPLY VENT, REFER TO MEP FOR NEW RETURN AND SUPPLY AIR LOCATIONS
- EXISTING RECESSED CAN LIGHTING
- RELOCATED EXISTING RECESSED CAN LIGHTING
- PENDANT LIGHT FIXTURE, RE: MEP
- LINEAR PENDANT LIGHT FIXTURE, RE: MEP
- ACOUSTIC BAFFLE, RE: FINISH LEGEND
- FIRE EXIT SIGN

CEILING PLAN KEY NOTES:


- 1 RELOCATE EXISTING LIGHT FIXTURE, RE: MEP.
- 2 REPLACE SOILED OR STAINED TILES, MATCH EXISTING, REFER TO GENERAL NOTE 15.
- 3 REPAIR GRID AND INFILL TILES, MATCH EXISTING, REFER TO GENERAL NOTE 14.
- 4 INSTALL PENDANT LIGHT CENTERED ON TABLE BELOW, REFER TO OWNER FOR FURNITURE PLAN.
- 5 INSTALL PENDANT LIGHT CENTERED IN ROOM.
- 6 CENTER ACOUSTICAL BAFFLES OVER WORKSTATIONS, VERIFY WORKSTATION SIZE & LAYOUT WITH ARCHITECT PRIOR TO INSTALLATION, REFER TO ALTERNATE #3.

GENERAL NOTES- REFLECTED CEILING PLANS:

- DIMENSIONS SHOWN ON THE REFLECTED CEILING PLANS ARE TO THE FACE OF GYP. BOARD (FOG), AND COLUMN GRID LINES, UNLESS NOTED OR SHOWN OTHERWISE.
- ALL CEILING HEIGHTS AS SHOWN ON PLANS AND DETAILS ARE FROM SLAB OR TILE FLOOR (FINISHED FLOOR) TO FINISH CEILING.
- AT ALL GYP. BD. SOFFITS: EXTEND GYP. BD. UP 6 INCHES ABOVE ADJACENT CEILING.
- RE: DETAILS FOR ADDITIONAL CONDITIONS AND CEILING HEIGHT INFORMATION.
- RE: FINISH LEGEND AND FINISH SCHEDULE FOR ROOM CEILING FINISHES.
- CEILING TILES/GRID TO BE CENTERED IN THE ROOM, UNLESS NOTED OTHERWISE.
- RECESSED LIGHTING, SPEAKERS, SMOKE DETECTORS, ETC. AND PENDANT LIGHT FIXTURES - SHALL BE CENTERED IN CEILING TILE OR GYP. BD. CEILING, UNLESS NOTED OTHERWISE.
- RE: INTERIOR ELEVATIONS FOR LOCATION OF WALL MOUNTED LIGHT FIXTURES
- RE: ELECTRICAL SHEETS AND SPECIFICATIONS FOR DETAILED INFORMATION ON LIGHT FIXTURE SCHEDULE.
- RE: MECHANICAL SHEETS AND SPECIFICATIONS FOR DETAILED INFORMATION ON DIFFUSERS
- COORDINATE ALL PENDANT MOUNTED LIGHT FIXTURES IN EQUIPMENT AREAS WITH EXPOSED STRUCTURE.
- COORDINATE ALL CEILING MOUNTED EQUIPMENT WITH CASEWORK BELOW.
- IF THERE IS A CONFLICT BETWEEN ANY ABOVE-CEILING MECHANICAL / ELECTRICAL / PLUMBING WORK & THE SCHEDULED OR SHOWN CEILING HEIGHT, CONTACT THE ARCHITECT IMMEDIATELY FOR CLARIFICATION.
- REPAIR GRID AND INFILL TILES AS NECESSARY; MATCH EXISTING ADJACENT CEILING TILE AND GRID FINISH & COLOR.
- REPLACE ALL DAMAGED AND/OR SOILED ACOUSTICAL CEILING TILES; MATCH EXISTING CEILING TILE PATTERN AND COLOR.











NOTES

1/8" = 1'-0"



1 FIRST FLOOR RCP

1/4" = 1'-0"



A400



PERFECT PROMOTIONS

1469 SW Market Street
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



06.13.22

project number 2022-018

date 05.25.2022


issued for PERMIT

rev date description

CASEWORK
SECTIONS &
INTERIOR
DETAILS

sheet number

A500



11		DETAIL -ACOUSTICAL BAFFLES (ALTERNATE 1 & 4)		10		DETAIL - HOLLOW METAL GLAZING	
		3" = 1'-0"				3" = 1'-0"	
9		DETAIL - INTERIOR STOREFRONT		8		WALL AT MULLION DETAIL	
		3" = 1'-0"				3" = 1'-0"	
7		MICROWAVE BASE		6		4 DRAWER BASE	
		1" = 1'-0"				1" = 1'-0"	
5		COUNTER W/ DW		4		SINK BASE	
		1" = 1'-0"				1" = 1'-0"	
3		DOOR & DRAWER BASE		2		SHORT UPPER	
		1" = 1'-0"				1" = 1'-0"	
1		UPPER					
		1" = 1'-0"					




PERFECT PROMOTIONS

1469 SW Market Street
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



06.13.22

project number 2022-018

date 05.25.2022

issued for PERMIT

rev date description

FINISH PLAN,
LEGEND &
SCHEDULES

sheet number

A600

ROOM FINISH SCHEDULE											
RM. NO.	ROOM NAME	FLOORS		WALL FINISH			CEILING FINISH	CASEWORK			COMMENTS
		FLOOR	WALL BASE	NORTH WALL	EAST WALL	SOUTH WALL		COUNTER TOP	BASE CABINET	UPPER CABINET	
101	ENTRY	SC-01	RWB-01	PNT-01	PNT-01	PNT-02	PNT-01	-			
102	CONF.	CPT-01	RWB-01	PNT-03	AWC-01	PNT-01	AWC-01	ACB-01			SEE ALTERNATES 3 & 4
103	OFFICE	CPT-01	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
104	OFFICE	CPT-01	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
105	OFFICE	CPT-01	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
106	STORAGE	SC-01	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
107	OFFICE	CPT-01	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
108	OPEN OFFICE	SC-01	RWB-01	PNT-01	PNT-01/ AWP-01	PNT-01	PNT-01/ AWP-01	ACB-01			SEE ALTERNATES 1, 2, & 5
108A	PRINT STATION	SC-01	RWB-01	PNT-04	PNT-01	PNT-01	PNT-01		SSM-01	HPL-01	
109	COLLAB SPACE	SC-01	RWB-01	-	PNT-01	PNT-01	PNT-01	ACT-01			
110	HUDDLE	CPT-01	RWB-01	PNT-01	PNT-01	PNT-01	AWC-02				SEE ALTERNATE 3
111	HUDDLE	CPT-01	RWB-01	PNT-01	AWC-02	PNT-01	PNT-01	-			SEE ALTERNATE 3
112	STORAGE	SC-01	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
113	BREAKROOM	SC-01	RWB-01	PNT-01/ WT-01	PNT-01	PNT-01	PNT-01/ WT-01	ACT-03	SSM-01	HPL-01	HPL-01
113A	CIRCULATION	SC-01	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
114	STOR.	-	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
115	I.T.	-	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
116	MECH.	SC-01	RWB-01	PNT-01	PNT-01	PNT-01	PNT-01	-			
117	WOMENS	-	-	-	-	-	-	-			
118	MENS	-	-	-	-	-	-	-			

ALTERNATES:

1. ALTERNATE #1: PROVIDE ACOUSTICAL CEILING BAFFLES (ACB-01) SUSPENDED FROM CEILING IN THE OPEN OFFICE. REFER TO RCP FOR QUANTITY AND LAYOUT. REFER TO FINISH LEGEND FOR PRODUCT INFORMATION.
2. ALTERNATE #2: PROVIDE ACOUSTICAL WALL PANELS (AWP-01) ON WALL. REFER TO ELEVATIONS FOR QUANTITY AND LAYOUT. REFER TO FINISH LEGEND FOR PRODUCT INFORMATION.
3. ALTERNATE #3: PROVIDE ACOUSTICAL WALL COVERINGS (AWC-01 & AWC-02) ON WALL. REFER TO FINISH PLAN AND FINISH SCHEDULE FOR LOCATION. REFER TO FINISH LEGEND FOR PRODUCT INFORMATION.
4. ALTERNATE #4: PROVIDE ACOUSTICAL CEILING BAFFLES (ACB-01) SUSPENDED FROM CEILING IN THE CONFERENCE ROOM. REFER TO RCP FOR QUANTITY AND LAYOUT. REFER TO FINISH LEGEND FOR PRODUCT INFORMATION.
5. ALTERNATE #5: REHANG EXISTING ACOUSTICAL CEILING GRID TO EXTENTS AS SHOWN ON THE RCP. ALIGN WITH EXISTING GRID. REUSE EXISTING CEILING GRID AND EXISTING CEILING TILE.

DOOR SCHEDULE											
DOOR #	ROOM: NAME	WIDTH	HEIGHT	DOOR MATERIAL	DOOR TYPE	FRAME MATERIAL	FIRE RATING	HARDWARE	HEAD	JAMB	REMARKS
102A	CONF.	3' - 0"	7' - 0"	WOOD	B	HM	-	1	3/A600	2/A600	
102B	CONF.	3' - 0"	7' - 0"	GLASS	A	ALUM.	-	1	10/A500	10/A500	
103	OFFICE	3' - 0"	7' - 0"	GLASS	B	HM	-	1	10/A500	10/A500	
104	OFFICE	3' - 0"	7' - 0"	GLASS	B	HM	-	1	10/A500	10/A500	
105	OFFICE	3' - 0"	7' - 0"	GLASS	B	HM	-	1	10/A500	10/A500	
106	STORAGE	3' - 0"	7' - 0"	WOOD	A	HM	-	2	3/A600	2/A600	
107	OFFICE	3' - 0"	7' - 0"	GLASS	B	HM	-	1	10/A500	10/A500	
108	OPEN OFFICE	3' - 0"	7' - 0"	WOOD	A	HM	-	3	3/A600	2/A600	
117	HUDDLE	3' - 0"	7' - 0"	GLASS	C	ALUM.	-	1	10/A500	10/A500	
118	HUDDLE	3' - 0"	7' - 0"	GLASS	C	ALUM.	-	1	10/A500	10/A500	
A	MECH.	3' - 0"	7' - 0"	-	-	-	-	-	-	-	EXISTING
B	BREAKROOM	3' - 0"	7' - 0"	-	-	-	-	-	-	-	EXISTING
C	STORAGE	3' - 0"	7' - 0"	-	-	-	-	-	-	-	EXISTING

GENERAL NOTES:

1. HM REFERS TO HOLLOW METAL
2. AL REFERS TO ALUMINUM
3. WD REFERS TO WOOD
4. ALL INTERIOR ALUMINUM DOORS & FRAMES ARE TO BE FINISHED TO MATCH ADJACENT EXTERIOR ALUMINUM WINDOW FRAME. U.N.O.
5. REFER TO FINISH LEGEND & GENERAL INTERIOR FINISH NOTES FOR FINISH OF INTERIOR DOORS AND FRAMES.
6. ALL GLAZING IN CODE SPECIFIED "HAZARDOUS LOCATIONS" (I.E. DOORS, SIDE LITES, ETC.) SHALL COMPLY WITH THE SAFETY GLAZING REQUIREMENTS AS OUTLINED IN SECTIONS 2406 AND 2406.3 OF THE IBC.
7. HARDWARE SET 1: PRIVACY DOOR HARDWARE.
8. HARDWARE SET 2: STORAGE DOOR HARWARE.
9. HARDWARE SET 2: PASSAGE DOOR HARWARE.

DOOR HEADER / JAMB SCHEDULE

OPENING	HEADER	JAMB STUDS
UP TO 4'-0"	2'-6" 18 GA	(2) 18 GA
4'-1" TO 8'-0"	2'-8" 16 GA	(3) 18 GA
8'-1" TO 12'-0"	2'-10" 16 GA	(4) 18 GA

NOTES:

1. FOR OPENINGS GREATER THAN 12'-0": STUDS ARE SUPPORTED VERTICALLY BY STRUCTURE AND HORIZONTALLY BY DIAGONAL BRACING. PROVIDE HEADER AND JAMB STUDS PER 8'-0" OPENING.
2. INCREASE JAMB STUD GAUGE IF HEIGHT REQUIRES IT.

GENERAL NOTES - WINDOW TYPES/ GLASS TYPES:




1. ALL DIMENSIONS ARE TO ROUGH OPENING AND TO TOP OR BOTTOM OF MULLION, UNLESS NOTED OR SHOWN OTHERWISE.
2. ALL OPENINGS ARE TO BE FIELD VERIFIED, AND NOTED AS SUCH ON SHOP DRAWINGS, PRIOR TO ARCHITECT'S REVIEW.
3. ALL GLAZING IN CODE SPECIFIED "HAZARDOUS LOCATIONS" (I.E. DOORS, SIDE LITES, ETC.) SHALL COMPLY WITH THE SAFETY GLAZING REQUIREMENTS AS OUTLINED IN SECTIONS 2406 AND 2406.3 OF THE IBC.

DOOR SCHEDULE

1 1/2" = 1'-0"

GLAZING NOTES

1/4" = 1'-0"



DOOR TYPES - INTERIOR

1/4" = 1'-0"

3

HM DOOR HEAD

3" = 1'-0"

2


HM DOOR JAMB

3" = 1'-0"

1

FINISH PLAN

1/8" = 1'-0"



MECHANICAL SPECIFICATIONS

1. GENERAL PROVISIONS:
- A. PROVIDE ALL LABOR, MATERIALS, AND EQUIPMENT NECESSARY FOR THE COMPLETE INSTALLATION OF THE MECHANICAL SYSTEMS OUTLINED.
 - B. OBTAIN ALL PERMITS, FEES, LICENSES, INSPECTIONS, AND CERTIFICATIONS OF COMPLIANCE OR APPROVAL AS REQUIRED BY AUTHORITIES.
 - C. ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE LAWS, CODES AND REGULATIONS OF THE GOVERNMENTAL BODIES HAVING JURISDICTION OVER THE SITE.
 - D. DURING CONSTRUCTION, ALL FIXTURES, EQUIPMENT, PIPE, DUCT, ETC. SHALL BE COVERED, PLUGGED, OR CAPPED AS REQUIRED TO KEEP CLEAN AND UNDAMAGED. ALL DAMAGED ITEMS SHALL BE RESTORED TO ORIGINAL CONDITION OR REPLACED. ALL PROTECTIVE COVERING SHALL BE REMOVED BEFORE FINAL ACCEPTANCE.
 - E. CONTRACTOR SHALL GUARANTEE ALL WORK AND MATERIALS AGAINST DEFECT FOR A PERIOD OF ONE YEAR FROM FINAL ACCEPTANCE.
 - F. FOR THE PURPOSE OF CLEARNESS AND LEGIBILITY, THE MECHANICAL AND DRAWINGS ARE ESSENTIALLY DIAGRAMMATIC AND DO NOT SHOW ALL OFFSETS AND FITTINGS REQUIRED FOR INSTALLATION. DO NOT SCALE DRAWINGS. THE SIZE AND LOCATION OF EQUIPMENT IS SHOWN TO SCALE WHEREVER POSSIBLE. THE CONTRACTOR SHALL VERIFY ALL CONDITIONS AND DATA AS INDICATED ON THE DRAWINGS AND IN THE SPECIFICATION SECTIONS WHERE MECHANICAL WORK INTERFACES WITH OTHER TRADES.

2. INSULATION:
- A. ALL INSULATIONS AND ACCESSORIES SHALL HAVE A FIRE HAZARD CLASSIFICATION WITH A FLAME SPREAD RATING OF NOT OVER 25, A FUEL CONTRIBUTION RATING OF NOT OVER 50, AND A SMOKE DEVELOPMENT RATING OF NOT OVER 50, IN ACCORDANCE WITH NFPA.
 - B. DUCTWORK INSULATION:
 - 1. DUCT COVERING: 3/4 LB/CF, FIBERGLASS BLANKET WITH FACTORY APPLIED VAPOR BARRIER AND FACING. THICKNESS AS SCHEDULED, INSTALLATION IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS. DUCT COVERING SHALL BE MINIMUM R-6.
 - a. SUPPLY AIR DUCT: 2"
 - b. RETURN AIR DUCT: 2"

3. TESTING, BALANCING AND CLEANING:
- A. DUCTWORK AND PIPING SHALL BE BALANCED. BALANCING SHALL INCLUDE THE BALANCING OF THE AIR DISTRIBUTION SYSTEMS TO PROVIDE DESIGN QUANTITIES INDICATED.


4. DUCTWORK:
- A. ALL DUCTWORK UNLESS OTHERWISE INDICATED SHALL BE FABRICATED FROM GALVANIZED SHEET STEEL COMPLYING WITH ASTM A 527, LOCKFORMING QUALITY, WITH G60 ZINC COATING IN ACCORDANCE WITH ASTM A 525, AND MILL PHOSPHATIZED FOR EXPOSED LOCATIONS.
 - B. DUCTWORK METAL GAUGES, REINFORCING, ETC SHALL BE CONSTRUCTED IN ACCORDANCE WITH SMACNA "HVAC DUCT CONSTRUCTION STANDARDS," LATEST EDITION FOR A 2" WATER GAUGE STATIC PRESSURE.
 - C. ALL FITTINGS SHALL BE CONSTRUCTED IN ACCORDANCE WITH SMACNA "HVAC DUCT CONSTRUCTION STANDARDS," LATEST EDITION.

5. FLEXIBLE DUCT:
- A. ATCO #086 (R-6), OR EQUAL.
 - B. FACTORY APPLIED INSULATION AND VAPOR BARRIER, 1-1/2" THICK.
 - C. MAXIMUM LENGTH OF 6'-0".

6. REMODELING WORK:
- A. THIS PROJECT INVOLVES CONSTRUCTION INSIDE AN EXISTING STRUCTURE. CONTRACTORS, BY SUBMITTING A BID ARE DEEMED TO BE COMPLETELY FAMILIAR WITH THE EXISTING CONDITIONS OF THE BUILDING AS IT INFLUENCES THE WORK DESCRIBED. NO CLAIMS FOR EXTRA COMPENSATION WILL BE CONSIDERED FOR EXISTING CONDITIONS VISIBLE OR REASONABLY INFERABLE FROM A CAREFUL EXAMINATION OF THE EXISTING BUILDING CONDITIONS.
 - B. CONTRACTOR SHALL INSPECT THE EXISTING FIELD CONDITIONS AT THE SITE AND THE CONTRACT DOCUMENTS PRIOR TO THE START OF ANY WORK TO DETERMINE WHAT EFFECT THE EXISTING CONDITIONS WILL HAVE ON THE WORK. POTENTIAL CONTRACTOR SHALL REPORT DISCREPANCIES TO THE ARCHITECT AND INCLUDE IN THE BID ALL COSTS REQUIRED TO MAKE THE WORK MEET EXISTING CONDITIONS.

KEYED PLAN NOTES

- 1. EXISTING DIFFUSER/RETURN TO REMAIN.
- 2. RELOCATE EXISTING SUPPLY DIFFUSER/RETURN GRILLE. EXTEND DUCTWORK AS NECESSARY TO MAKE CONNECTION AT NEW LOCATION.
- 3. NEW DIFFUSER EQUAL TO TITUS PAS. COORDINATE COLOR WITH ARCHITECT. CONNECTION SUPPLY DUCT TO NEAREST MAIN TRUNK.
- 4. PROVIDE RETURN GRILLE EQUAL TO TITUS PAR. COORDINATE COLOR WITH ARCHITECT. MAKE 10" DUCT CONNECTION TO EXISTING RETURN AIR TRUNK IN AREA.
- 5. EXISTING EXHAUST FAN TO REMAIN. FIELD VEIFY EXHAUST TERMINATES TO EXTERIOR.
- 6. PROVIDE RETURN GRILLE ON EACH SIDE OF WALL, TITUS PAR OR EQUAL, WITH FLEX DUCT BETWEEN GRILLES.




MECHANICAL PLAN

SCALE : 1/4" = 1'-0"

1



MEP ENGINEER



MO COA NO. 2012006786 / KS COA NO. E-2818
1925 CENTRAL ST., STE. 201
KANSAS CITY, MO 64108
phone: (816) 272-5289, email: jsmothers@jsscengineers.com

PERFECT PROMOTIONS

1469 SW MARKET STREET
LEE'S SUMMIT, MO 64081
HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



project number 22-083

date 05.25.2022

issued for PERMIT

rev date description

MECHANICAL PLAN

sheet number

M101

PLUMBING SPECIFICATIONS

1. GENERAL PROVISIONS:
- A. PROVIDE ALL LABOR, MATERIALS, AND EQUIPMENT NECESSARY FOR THE COMPLETE INSTALLATION OF THE PLUMBING SYSTEMS OUTLINED.
- B. OBTAIN ALL PERMITS, FEES, LICENSES, INSPECTIONS, AND CERTIFICATIONS OF COMPLIANCE OR APPROVAL AS REQUIRED BY AUTHORITIES.
- C. ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE LAWS, CODES AND REGULATIONS OF THE GOVERNMENTAL BODIES HAVING JURISDICTION OVER THE SITE.
- D. CONTRACTOR SHALL GUARANTEE ALL WORK AND MATERIALS AGAINST DEFECT FOR A PERIOD OF ONE YEAR FROM FINAL ACCEPTANCE.
- E. INSPECTION OF THE SITE: THIS CONTRACTOR SHALL THOROUGHLY ACQUAINT HIMSELF WITH THE MEP DRAWINGS, SPECIFICATIONS, DETAIL, AND THE SITE. THIS CONTRACTOR SHALL NOTIFY THE ARCHITECT OF ANY SPECIAL OR UNUSUAL PROBLEMS, CONFLICTS, OR OBSTRUCTIONS THAT AFFECT HIS BID.
- F. FOR THE PURPOSE OF CLEARNESS AND LEGIBILITY, THE PLUMBING DRAWINGS ARE ESSENTIALLY DIAGRAMMATIC AND DO NOT SHOW ALL OFFSETS AND FITTINGS REQUIRED FOR INSTALLATION. DO NOT SCALE DRAWINGS. THE SIZE AND LOCATION OF EQUIPMENT IS SHOWN TO SCALE WHEREVER POSSIBLE. THE CONTRACTOR SHALL VERIFY ALL CONDITIONS AND DATA AS INDICATED ON THE DRAWINGS AND IN THE SPECIFICATION SECTIONS WHERE MECHANICAL WORK INTERFACES WITH OTHER TRADES.
- G. INSTALL MATERIALS AND SYSTEMS IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND APPROVED SUBMITTALS. INSTALL MATERIALS IN PROPER RELATION WITH ADJACENT CONSTRUCTION AND WITH UNIFORM APPEARANCE FOR EXPOSED WORK. COORDINATE WITH WORK OF OTHER SECTIONS. COMPLY WITH APPLICABLE REGULATIONS AND CODE REQUIREMENTS. PROVIDE PROPER CLEARANCES FOR SERVING.
- H. INCLUDE ALL BASIC MATERIALS AND CONSTRUCTION METHODS INCLUDING PIPES, PIPE FITTINGS, AND SPECIALTIES AND SUPPORTING DEVICES, VALVES, PIPE AND VALVE IDENTIFICATION, PUMPS, VIBRATION ISOLATION, ETC.
- I. FURNISH ADEQUATE ACCESS PANELS AND DOORS TO ALLOW FOR FUTURE PIPING ALTERATIONS, REPLACEMENT, AND MAINTENANCE OF PIPING. PROPERLY IDENTIFY ALL ACCESS PANELS AND DOORS.

2. PLUMBING:
- A. PROVIDE AN APPROVED WATER HAMMER ARRESTOR FOR EACH PLUMBING FIXTURE SUPPLY AS REQUIRED BY FIXTURE MANUFACTURER.
- B. ALL EXPOSED PIPE IN FINISHED AREAS SHALL BE CHROME PLATED BRASS PIPE, NO FERROUS PIPE.
- C. PROVIDE CLEANOUTS AT EACH CHANGE IN DIRECTION AND AT 100 FOOT INTERVALS IN STRAIGHT RUNS.
- D. ALL SEWER PIPING LOCATED INSIDE THE BUILDING SHALL BE INSTALLED WITH THE FOLLOWING SLOPES.
1. INSTALL 2-1/2" AND SMALLER PIPE AT 1/4" PER FOOT FALL.
2. INSTALL 3" AND LARGER PIPE AT 1/8" PER FOOT FALL.

3. PIPING
- A. DOMESTIC COLD, HOT, AND HOT WATER RECIRCULATING (ABOVEGROUND).
1. TYPE L HARD DRAWN COPPER TUBING, ASTM B-88 WITH WROUGHT BRONZE SOLDERED FITTINGS.
- 2.
- B. SANITARY SEWER AND VENTS (UNDERGROUND, INTERIOR TO BUILDING).
1. WASTE, DRAIN AND VENT PIPE AND FITTINGS, THROUGHOUT THE BUILDING BELOW THE BASE SLAB TO THE LOCATIONS NOTED OUTSIDE OF THE BUILDING SHALL BE ASTM D2665 POLYVINYL CHLORIDE (PVC) DWV PIPE, SCHEDULE 40, SOLVENT JOINT.
2. SEWER LINES SHALL BE LOCATED IN GENERAL AS SHOWN ON THE DRAWINGS. THE EXACT LOCATIONS SHALL BE DETERMINED BY THE CONTRACTOR IN SUCH A MANNER AS TO MAINTAIN PROPER CLEARANCES AND SUFFICIENT SLOPE TO ENSURE DRAINAGE.


4. INSULATION:
- A. ALL INSULATIONS AND ACCESSORIES SHALL HAVE A FIRE HAZARD CLASSIFICATION WITH A FLAME SPREAD RATING OF NOT OVER 25, A FUEL CONTRIBUTION RATING OF NOT OVER 50, AND A SMOKE DEVELOPMENT RATING OF NOT OVER 50, IN ACCORDANCE WITH NFPA.
- B. PIPE INSULATION (ABOVE GRADE):
1. THE PIPE INSULATION USED SHALL HAVE A THERMAL CONDUCTIVITY OF 0.27 BTU PER IN*SQ-FT*F OR LESS.
2. FLEXIBLE CLOSED CELL ELASTOMERIC THERMAL INSULATION, UNSLIT OR PRESLIT WITH PRESSURE SENSITIVE ADHESIVE SYSTEM FOR CLOSURE AND VAPOR SEALING, EQUAL TO ARMSTRONG AP ARMAFLEX OR ARMAFLEX 2000.
3. INSULATION SCHEDULE:
- a. DOMESTIC HOT WATER: 1"

4. TESTING, BALANCING AND CLEANING:
- A. ALL PIPING SHALL BE TESTED FOR LEAKS BEFORE BEING CONCEALED IN WALL CONSTRUCTION OR COVERED WITH INSULATION.
- B. SEWER AND VENT PIPING SHALL BE HYDROSTATICALLY TESTED WITH NO LESS THAN 10 FEET OF HEAD FOR A PERIOD OF NOT LESS THAN 15 MINUTES, PER THE LOCAL PLUMBING CODE, WITH NO LEAKS.
- C. DOMESTIC WATER PIPING SHALL BE HYDROSTATICALLY TESTED AT A PRESSURE OF NOT LESS THAN 1-1/2 TIMES THE OPERATING PRESSURE, BUT NOT LESS THAN 60 PSI, FOR A PERIOD OF NOT LESS THAN 2 HOURS, WITH NO LEAKS.

5. REMODELING WORK:
- A. THIS PROJECT INVOLVES CONSTRUCTION INSIDE AN EXISTING STRUCTURE. CONTRACTORS, BY SUBMITTING A BID ARE DEEMED TO BE COMPLETELY FAMILIAR WITH THE EXISTING CONDITIONS OF THE BUILDING AS IT INFLUENCES THE WORK DESCRIBED. NO CLAIMS FOR EXTRA COMPENSATION WILL BE CONSIDERED FOR EXISTING CONDITIONS VISIBLE OR REASONABLY INFERRABLE FROM A CAREFUL EXAMINATION OF THE EXISTING BUILDING CONDITIONS.
- B. CONTRACTOR SHALL INSPECT THE EXISTING FIELD CONDITIONS AT THE SITE AND THE CONTRACT DOCUMENTS PRIOR TO THE START OF ANY WORK TO DETERMINE WHAT EFFECT THE EXISTING CONDITIONS WILL HAVE ON THE WORK POTENTIAL. CONTRACTOR SHALL REPORT DISCREPANCIES TO THE ARCHITECT AND INCLUDE IN THE BID ALL COSTS REQUIRED TO MAKE THE WORK MEET EXISTING CONDITIONS.

KEYED PLAN NOTES

1. MAKE CONNECTION TO EXISTING SANITARY SEWER & VENT PIPING FROM PREVIOUS RESTROOM REMOVED IN DEMOLITION SCOPE. LOCATE EXACT TIE-IN POINT ON SITE PRIOR TO CONSTRUCTION.
2. PROVIDE DISHWASHER DRAIN TO CONNECTION AT GARBAGE DISPOSAL. ROUTE TO UNDERSIDE OF COUNTERTOP TO CREATE HIGH LOOP THEN BACK DOWN TO GARBAGE DISPOSAL CONNECTION.
3. EXISTING PLUMBING EQUIPMENT & PIPING IN THIS ROOM IS TO REMAIN. CONFIRM THAT ALL EQUIPMENT & CONNECTIONS EXIST IN COMPLIANCE WITH LOCAL CODES & ORDINANCES PRIOR TO COMPLETION OF CONSTRUCTION.
4. DEMO & CAP EXISTING PIPING IN FLOOR OR ABOVE CEILING AND REPAIR FLOOR AS NECESSARY TO MATCH SURROUNDING CONDITIONS. COORDINATE EXACT SCOPE REQUIREMENTS WITH GC PRIOR TO CONSTRUCTION.
5. CAP EXISTING PLUMBING IN WALL. COORDINATE EXACT SCOPE REQUIREMENTS WITH GC PRIOR TO CONSTRUCTION.



PLUMBING PLAN - WASTE AND VENT

SCALE : 1/4" = 1'-0"

1



PERFECT PROMOTIONS

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



project number 22-083

date 05.25.2022


issued for PERMIT

rev	date	description
-----	------	-------------


PLUMBING PLAN

sheet number

P101



MEP ENGINEER



MO COA NO. 2012006786 / KS COA NO. E-2818
1925 CENTRAL ST., STE. 201
KANSAS CITY, MO 64108

phone: (816) 272-5285, email: jsmothers@jsscengineers.com

1469 SW MARKET STREET
LEE'S SUMMIT, MO 64081


HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

GENERAL NOTES

- A. DRAWINGS ARE DIAGRAMMATIC ONLY AND REPRESENT THE GENERAL SCOPE OF WORK. REVIEW THE GENERAL NOTES, SPECIFICATIONS AND PLANS FOR ADDITIONAL REQUIREMENTS THAT MAY NOT BE SPECIFICALLY CALLED OUT IN THIS PORTION OF THE CONSTRUCTION DOCUMENTS. NOTIFY ARCHITECT, ENGINEER AND/OR OWNER OF CONFLICTS OR DISCREPANCIES PRIOR TO SUBMISSION OF BID.
- B. COORDINATE INSTALLATION OF MECHANICAL AND PLUMBING SYSTEMS WITH OTHER TRADES TO ENSURE A NEAT AND ORDERLY INSTALLATION AND AVOID CONFLICTS. INSTALL DUCTWORK AND PIPING AS TIGHT TO STRUCTURE AS POSSIBLE. COORDINATE INSTALLATION OF DUCTWORK AND PIPING TO AVOID CONFLICTS WITH ELECTRICAL PANELS, LIGHTING FIXTURES, ETC. VERIFY DUCT SPACE AVAILABLE ABOVE ALL CEILINGS PRIOR TO ANY FABRICATION OF INSTALLATION.
- C. NEW MECHANICAL EQUIPMENT, DUCTWORK AND PIPING ARE SHOWN AT APPROXIMATE LOCATIONS. FIELD MEASURE FINAL DUCTWORK AND PIPING LOCATIONS PRIOR TO FABRICATION AND MAKE ADJUSTMENTS AS REQUIRED TO FIT THE DUCTWORK AND PIPING WITHIN THE AVAILABLE SPACE. VERIFY THAT FINAL EQUIPMENT LOCATIONS MEET MANUFACTURER'S RECOMMENDATIONS REGARDING SERVICE CLEARANCE AROUND EQUIPMENT.
- D. BRANCH DUCTWORK SHALL BE THE SAME SIZE AS NECK SIZE SHOWN UNLESS OTHERWISE NOTED.
- E. ALL ROOF AND WALL PENETRATIONS SHALL BE COORDINATED WITH THE GENERAL CONTRACTOR. PROVIDE ALL REQUIRED SLEEVES, FLASHINGS, CURBS, REINFORCED ANGLES, SUPPORTING FRAMES, ETC. UNLESS THEY ARE SPECIFICALLY CALLED OUT TO BE FURNISHED BY OTHERS.
- F. THE ELECTRICAL SYSTEM DESIGN IS BASED IN PART ON THE SPECIFIED HVAC EQUIPMENT. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO COORDINATE THE ELECTRICAL REQUIREMENTS OF THE HVAC EQUIPMENT BEING FURNISHED. ANY CHANGES TO THE ELECTRICAL SYSTEM DUE TO HVAC EQUIPMENT OTHER THAN THE SPECIFIED EQUIPMENT BEING FURNISHED SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.

KEYED PLAN NOTES

1. EQUIPMENT, FIXTURES, AND PIPING IN THIS ROOM ARE EXISTING TO REMAIN.
2. MAKE CONNECTION TO EXISTING COLD & HOT WATER PIPING IN AREA.
3. PROVIDE UNDERMOUNT SINK: ELKAY ELUH211510PD, SINGLE BASIN, STAINLESS STEEL, WITH SINGLE LEVER PULL-OUT FAUCET (DELTA 9113-DST), CHROME FINISH. PROVIDE FLEXIBLE SS RISERS WITH CHROME PLATED STOP VALVES, P-TRAP WITH CLEANOUT, AND BADGER 5 1/2HP GARBAGE DISPOSAL.
4. PROVIDE ICE MAKER OUTLET BOX WITH WATER HAMMER ARRESTOR, SIOUX CHIEF MODEL 696 OR EQUAL.




PLUMBING PLAN - WATER

SCALE : 1/4" = 1'-0"

1



MEP ENGINEER



MO COA NO. 2012008786 / KS COA NO. E-2818
1925 CENTRAL ST., STE. 201
KANSAS CITY, MO 64108
phone: (816) 272-5285, email: jsmothers@jscengineers.com


PERFECT PROMOTIONS

1469 SW MARKET STREET
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



project number 22-083

date 05.25.2022

issued for PERMIT

rev	date	description
-----	------	-------------

PLUMBING PLAN

sheet number

P102

ELECTRICAL SPECIFICATIONS

PART I – GENERAL

A. GENERAL

- FURNISH AND INSTALL A COMPLETELY WIRED AND OPERATIONAL ELECTRICAL SYSTEM AS SHOWN ON THE DRAWINGS AND SPECIFIED HEREIN, INCLUDING BUT NOT LIMITED TO, THESE MAJOR ITEMS.
A. LIGHTING FIXTURES AS INDICATED AND SPECIFIED ON THE PLANS.
B. ELECTRICAL PANELS, SERVICE, CONDUIT, WIRING, ETC., FOR ALL OUTLETS AND EQUIPMENT.
C. TELEPHONE, TELEVISION, AND FIRE ALARM. OUTLETS AND CONDUIT AS INDICATED.
- OBTAIN AND REVIEW ALL OTHER DRAWINGS INCLUDING REFLECTED CEILING PLAN, INTERIOR AND EXTERIOR ELEVATIONS, FURNITURE PLANS AND ALL MILL WORK DRAWINGS. COORDINATE INSTALLATION OF ALL ELECTRICAL DEVICES AND EQUIPMENT PRIOR TO ROUGH-IN.
- OBTAIN SUBMITTAL AND SHOP DRAWINGS FROM OTHER TRADES AND EQUIPMENT TO COORDINATE INSTALLATION ACCORDINGLY.
- INSTALLATION SHALL COMPLY WITH ALL CURRENT APPLICABLE CODES AND GOVERNING AGENCIES HAVING JURISDICTION.
- FIRE ALARM SYSTEM, IF REQUIRED PER IBC, SHALL BE DESIGN-BUILD BY OWNER'S/CC'S FIRE ALARM CONTRACTOR. DESIGN SHALL BE IN ACCORDANCE WITH NFPA 72. FIRE ALARM CONTRACTOR SHALL SUBMIT STAMPED DRAWINGS TO AHJ FOR REVIEW AND APPROVAL. FIRE ALARM CONTRACTOR IS RESPONSIBLE FOR TESTING AND VERIFYING THAT THE AUDIBILITY OF THE FIRE ALARM SYSTEM MEETS A MINIMUM OF 15 DBA ABOVE AMBIENT NOISE LEVELS. ADD HORNS WHERE REQUIRED TO MAINTAIN MINIMUM LEVELS.
- PROVIDE FIRE STOP ON ALL PIPING THAT PENETRATES RATED WALLS. METHOD OF FIRE STOP SHALL MEET WALL RATING. REFER TO ARCHITECTURAL DRAWINGS FOR LOCATION OF FIRE RATED WALLS. THIS CONTRACTOR SHALL PROVIDE FIRE RATED ENCLOSURES AROUND ALL ROUGH-IN BOXES, PANELS, ETC. THAT ARE LOCATED IN FIRE RATED WALLS AND SHALL FIRE CAULK ALL OPENINGS IN RATED ASSEMBLIES.

B. RELATED WORK BY OTHERS

- THE ELECTRICAL CONTRACTOR SHALL PROVIDE CONDUIT, TRENCH, AND BACKFILL FOR ELECTRICAL SERVICE ENTRANCE FROM THE MAIN SERVICE TO UTILITY POINT OF ELECTRICAL SERVICE. ELECTRICAL CONTRACTOR SHALL COORDINATE THE INSTALLATION OF THE ELECTRICAL SERVICE ENTRANCE WITH SERVING UTILITY COMPANY.
- THE ELECTRICAL CONTRACTOR SHALL PROVIDE CONDUIT, TRENCH, AND BACKFILL FOR PRIMARY PHONE AND CATV SERVICE FROM THE TELEPHONE TERMINAL BOARD OR CABINET TO THE PHONE COMPANY AND CATV COMPANY POINT OF SERVICE. COORDINATE WITH LOCAL UTILITY COMPANIES.

C. CODES, REGULATIONS, AND STANDARDS

- THE INSTALLATION SHALL COMPLY WITH APPLICABLE LOCAL AND STATE CODES AND ORDINANCES, WITH THE REGULATIONS OF THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE AND WITH THE REQUIREMENTS OF THE POWER, TELEPHONE, AND CATV COMPANIES FURNISHING SERVICES TO THIS INSTALLATION.
- THE LATEST EDITIONS OF THE FOLLOWING INDUSTRY STANDARDS, SPECIFICATIONS, AND CODES ARE MINIMUM REQUIREMENTS:
A. THE NATIONAL ELECTRICAL MANUFACTURER'S ASSOCIATION STANDARDS.
B. THE NATIONAL ELECTRICAL CODE, INCLUDING LOCAL AMENDMENTS.
C. UNDERWRITER LABORATORIES INCORPORATED STANDARDS.
D. AMERICAN NATIONAL STANDARDS INSTITUTE.
E. INTERNATIONAL BUILDING CODE.

D. INSPECTION OF SITE

- PRIOR TO SUBMITTING A BID FOR ELECTRICAL WORK, THE CONTRACTOR SHALL VISIT THE SITE OF THE PROPOSED CONSTRUCTION AND SHALL THOROUGHLY ACQUAINT HIMSELF WITH EXISTING UTILITIES, AND WORKING CONDITIONS TO BE ENCOUNTERED, ETC. ALLOWANCE WILL NOT BE MADE FOR NONCOMPLANCE WITH THIS CONDITION AFTER BIDDING.
- ELECTRICAL INSTALLATION SHALL MEET THE EXISTING CONDITIONS.

E. STORAGE AND HANDLING OF MATERIAL

- DELIVER MATERIALS AND EQUIPMENT TO THE PROJECT IN THE MANUFACTURER'S ORIGINAL, UNOPENED, LABELED CONTAINERS. PROTECT AGAINST MOISTURE, TAMPERING, OR DAMAGE FROM IMPROPER HANDLING OR STORAGE. CONTRACTOR SHALL PROTECT AND BE RESPONSIBLE FOR ANY DAMAGE TO WORK OR MATERIALS UNTIL FINAL ACCEPTANCE BY THE OWNER, AND SHALL MAKE GOOD WITHOUT COST TO THE OWNER, ANY DAMAGE OR LOSS THAT MAY OCCUR DURING THIS PERIOD.
- ARRANGE FOR TIMELY DELIVERY OF MATERIALS AND EQUIPMENT TO THE JOB SITE IN ORDER TO MINIMIZE THE LENGTH OF TIME BETWEEN DELIVERY AND INSTALLATION.
- COVER AND PROTECT ANY MATERIAL WHICH MAY BE AFFECTED BY THE WEATHER WHILE IN TRANSIT OR STORED AT THE PROJECT SITE. ANY MATERIAL FOUND DEFECTIVE OR NOT INSTALLED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS MAY BE REJECTED BY THE ENGINEER.

F. CLEANUP

- KEEP THE PREMISES FREE FROM ACCUMULATION OF WASTE MATERIALS, OR RUBBISH CAUSED BY EMPLOYEES OR WORK UNDER THIS DIVISION OF THE SPECIFICATIONS. AT THE COMPLETION OF THE WORK REMOVE ALL SURPLUS MATERIALS, TOOLS, ETC., AND LEAVE THE PREMISES BROOM-CLEAN.

G. EXCAVATION, CUTTING, AND FITTING

- PERFORM ALL EXCAVATION AND BACK FILLING REQUIRED FOR WORK PERFORMED UNDER THIS DIVISION OF THE SPECIFICATIONS. USE EXCAVATED MATERIALS FOR BACKFILL UNLESS OFF SITE MATERIALS ARE DEEMED NECESSARY.
- PERFORM THE EXCAVATION, CUTTING, FITTING, REPAIRING, AND FINISHING OF THE WORK NECESSARY FOR THE INSTALLATION OF THE EQUIPMENT OF THIS SECTION. HOWEVER, NO CUTTING OF THE WORK OF OTHER TRADES OR OF ANY STRUCTURAL MEMBERS SHALL BE DONE WITHOUT THE CONSENT OF THE ARCHITECT.

H. DRAWINGS

- THE DRAWINGS INDICATE THE GENERAL ARRANGEMENT AND LOCATIONS OF THE ELECTRICAL WORK. DATA PRESENTED ON THESE DRAWINGS ARE AS ACCURATE AS PLANNING CAN DETERMINE, BUT FIELD VERIFICATION OF ALL DIMENSIONS, LOCATIONS, LEVELS, ETC., TO SUIT FIELD CONDITIONS IS REQUIRED. REVIEW ALL ARCHITECTURAL, STRUCTURAL, AND MECHANICAL DRAWINGS AND ADJUST ALL WORK TO MEET THE REQUIREMENTS OF CONDITIONS SHOWN. THE ARCHITECTURAL DRAWINGS SHALL TAKE PRECEDENCE OVER ALL OTHER DRAWINGS. DISCREPANCIES BETWEEN DIFFERENT PLANS; OR BETWEEN DRAWINGS AND SPECIFICATIONS, OR REGULATIONS AND CODES GOVERNING THE INSTALLATION SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER IN WRITING BEFORE THE DATE OF BID OPENING. IF DISCREPANCIES ARE NOT REPORTED, THE CONTRACTOR SHALL BID THE GREATER QUANTITY OR BETTER QUALITY, AND APPROPRIATE ADJUSTMENTS WILL BE MADE AFTER CONTRACT AWARD. CONTRACTOR SHALL BE RESPONSIBLE TO FIELD MEASURE AND CONFIRM MOUNTING HEIGHTS AND LOCATION OF ELECTRICAL EQUIPMENT WITH RESPECT TO COUNTERS, RADIATION, ETC. DO NOT SCALE DISTANCES OFF THE ELECTRICAL DRAWINGS, USE ACTUAL BUILDING DIMENSIONS.

I. COOPERATION WITH OTHER CONTRACTORS

- COOPERATE WITH THE OTHER TRADES SO THAT THE INSTALLATION OF THE ELECTRICAL OUTLETS AND EQUIPMENT WILL BE PROPERLY COORDINATED. CONDUIT, LIGHTING FIXTURES, AND OTHER EQUIPMENT LOCATIONS SHALL BE VERIFIED WITH OTHER TRADES TO AVOID CONFLICT WITH THE PIPING, DUCTWORK, STEEL, BEAMS, OR OTHER OBSTRUCTIONS.
- CAREFULLY VERIFY THE LOCATIONS OF THE OUTLET BOXES AND DETERMINE THAT THEY HAVE NOT BEEN DISTURBED DURING THE INSTALLATION OF MATERIALS OF OTHER TRADES.
- COORDINATE THE LOCATION OF THE TRENCHES AND CONDUITS FOR ELECTRICAL AND TELEPHONE UTILITY SERVICES WITH THE GENERAL CONTRACTOR.
- COORDINATE HVAC AND PLUMBING EQUIPMENT CONNECTION REQUIREMENTS WITH HVAC AND PLUMBING CONTRACTORS.

J. RECORD DRAWINGS

- THE ELECTRICAL CONTRACTOR SHALL MAINTAIN A SET OF DRAWINGS AT THE JOB SITE FOR THE EXCLUSIVE PURPOSE OF MAINTAINING A RECORD OF ALL WORK INSTALLED AND TO SHOW ANY DEVIATIONS FROM THE WORK INDICATED ON THE DRAWINGS.
- AT THE COMPLETION OF THE PROJECT, ONE SET OF REPRODUCIBLE DRAWINGS, SHOWING ALL RECORD CONDITIONS, SHALL BE DELIVERED TO THE OWNER FOR ACCEPTANCE PRIOR TO FINAL PAYMENT.

PART II – PRODUCTS AND EXECUTION

A. MATERIALS

- ALL MATERIALS SHALL BE NEW AND OF QUALITY AS SPECIFIED ON THE PLANS OR SPECIFICATIONS AND MUST CARRY THE UNDERWRITER'S LABORATORIES APPROVAL COVERING THE PURPOSE FOR WHICH THEY ARE USED, IN ADDITION TO MEETING ALL REQUIREMENTS OF THE CURRENT APPLICABLE CODES AND REGULATIONS.

B. SHOP DRAWINGS AND APPROVALS

- THE ITEMS SPECIFIED HEREIN AND ON DRAWINGS ARE USED AS A STANDARD OF QUALITY. ANY MATERIALS OF EQUAL QUALITY AND AESTHETIC VALUE WILL BE GIVEN CONSIDERATION AS A SUBSTITUTE FOR THE MATERIALS SPECIFIED. NO APPROVAL WILL BE GIVEN TO A SPECIFIC CATALOG NUMBER, MODEL, OR TYPE OF EQUIPMENT, PRIOR TO BIDDING. AFTER BIDDING, THE DECISION OF THE

- ARCHITECT AND/OR ENGINEER DETERMINING EQUAL MATERIALS WILL BE FINAL.
- THE CONTRACTOR SHALL SUBMIT (3) IDENTICAL BOUND SETS OF SHOP DRAWINGS ON THE FOLLOWING ITEMS TO THE C.C.:
A. LIGHTING FIXTURE CUTS AND PERFORMANCE DATA.
B. OUTLINE DRAWINGS AND DATA SHEETS OF EACH PANELBOARD, LOAD CENTERS, AND DISTRIBUTION PANELS.
C. OUTLINE DRAWINGS OF ALL SWITCH GEAR COMPONENTS.
D. WIRING DEVICES AND COVERPLATES.
E. ALL CIRCUIT BREAKERS INSTALLED IN PANELBOARDS, LOAD CENTERS, AND DISTRIBUTION PANELS.

C. SYSTEM GROUNDING

- GROUNDING SHALL COMPLY WITH REQUIREMENTS OF ARTICLE 250. ALL EXPOSED NONCURRENT CARRYING METALLIC PARTS OF ELECTRICAL EQUIPMENT, METALLIC RACEWAY SYSTEMS, METALLIC CABLE ARMOR, GROUNDING CONDUCTOR OF NONMETALLIC SHEATHED CABLES, GROUNDING CONDUCTOR IN NONMETALLIC RACEWAYS, AND GROUNDING CONDUCTORS OF THE WIRING SYSTEM SHALL BE GROUNDED.
- GROUNDING CONDUCTOR (NEUTRAL) OF THE WIRING SYSTEM SHALL BE CONNECTED TO THE SYSTEM GROUNDING CONDUCTOR AT A SINGLE PLACE IN EACH SYSTEM BY REMOVABLE BONDING JUMPERS, SIZED ACCORDING TO THE APPLICABLE PROVISIONS OF THE NATIONAL ELECTRICAL CODE. THE GROUNDED CONDUCTOR (NEUTRAL) TO THE GROUNDING CONDUCTOR CONNECTION SHALL BE LOCATED IN THE ENCLOSURE FOR THE SYSTEM'S OVERCURRENT PROTECTION OR WHERE OTHERWISE INDICATED ON THE PLANS OR SPECIFICATIONS.
- A GROUND BUS SEPARATE FROM THE NEUTRAL BUS SHALL BE PROVIDED IN ALL DISTRIBUTION PANELS AND PANELBOARDS. PROPER TORQUE ON GROUND BUS SHALL BE VERIFIED, PER MANUFACTURER'S RECOMMENDATIONS, PRIOR TO ENERGIZING EQUIPMENT.
- GROUND BUSES AND NEUTRAL BUSES IN ALL DISTRIBUTION PANELS, LOAD CENTERS, PANELBOARDS, AND THOSE PROVIDED IN ANY EQUIPMENT SHALL BE ISOLATED EXCEPT WHERE REQUIRED TO BE CONNECTED AS SPECIFIED ABOVE FOR THE SERVICE ENTRANCE.
- WHEN INDICATED ON THE DRAWINGS, EQUIPMENT GROUNDING CONDUCTORS SHALL BE EXTENDED FROM THE GROUND BUS IN THE DISTRIBUTION EQUIPMENT TO THE RECEPTACLE, FIXTURE OR DEVICE LUGS WHERE THEY ARE PROVIDED. WHERE LUGS ARE NOT PROVIDED, EQUIPMENT GROUNDING CONDUCTORS SHALL BE CONNECTED TO EQUIPMENT ENCLOSURES. THE CONNECTIONS SHALL BE ARRANGED SUCH THAT REMOVAL OF THE RECEPTACLE, EQUIPMENT GROUND CONDUCTORS, OR GROUND JUMPERS FROM GROUND BUSING SHALL NOT AFFECT THE GROUND SYSTEM.
- RACEWAYS MAY NOT BE USED AS A GROUNDING CONDUCTOR FOR POWER AND LIGHTING CIRCUITS. ALL CONDUIT SHALL HAVE SEPARATE CODE SIZED GREEN GROUND WIRE INSTALLED IN THE CONDUIT TO INSURE A CONTINUOUS GROUNDING PATH.
- IN INACCESSIBLE LOCATIONS, MAKE CONNECTIONS BY EXOTHERMIC WELD PROCESS.
- IN ACCESSIBLE LOCATIONS, CONNECTIONS SHALL BE MADE WITH BOLTED THROUGH, APPROVED SOLDERLESS BRONZE GROUNDING DEVICES.

D. WIRE

- CONDUCTOR SIZES SHOWN ON THE DRAWINGS ARE BASED ON COPPER WIRE. UNLESS OTHERWISE SPECIFIED, ALL WIRE SHALL BE TYPE XHHW OR SE FOR FEEDERS OR BRANCH CIRCUITS LARGER THAN 4 AWG, TYPE THHN/THWN INSULATION FOR FEEDERS AND BRANCH CIRCUITS 4 AWG AND SMALLER. ALL BRANCH CIRCUIT WIRING SHALL BE COPPER.
A. ALUMINUM CONDUCTORS MAY BE UTILIZED FOR SERVICE ENTRANCE AND PANEL FEEDERS. CONDUCTORS SHALL BE ALUMINUM ALLOY AA-8000 SERIES.
2. THE WIRES SHALL BE MARKED WITH COLOR TO SIMPLIFY CIRCUIT IDENTIFICATION. UNLESS OTHERWISE REQUIRED BY LOCAL ORDINANCES GROUND WIRES SHALL BE GREEN, NEUTRAL WIRES SHALL BE 120V-WHITE [277V-GREY], LIVE WIRES 480Y/277V SHALL BE BROWN (PHASE A), ORANGE (PHASE B), AND YELLOW (PHASE C); AND LIVE WIRES 208Y/120V AND 120/240V SHALL BE BLACK (PHASE A), RED (PHASE B), AND BLUE (PHASE C). WHERE BOTH 208Y/120V AND 120/240V EXIST IN THE SAME BUILDING, THE CONDUCTORS OF EACH CONFIGURATION SHALL BE SEPARATELY IDENTIFIED (NOT THE SAME COLORS). "HIGH-LEG" PHASE OF DELTA SYSTEM SHALL ALWAYS BE MARKED ORANGE. CIRCUIT SHALL BE LABELED IN EACH J-BOX.
A. ALL CONDUCTORS SHALL BE RATED 600 VOLT.
3. SPLICES IN EXTERIOR PULL BOXES AND MANHOLES SHALL BE WEATHERPROOF USING "SCOTCHCAST" SPlice KIT OR APPROVED EQUAL. SEAL ENDS OF CONDUITS AND DUCTS WITH "DUCTSEAL" OR APPROVED EQUAL.
4. PROVIDE SOLID CONDUCTOR FOR 10 AWG AND SMALLER.
5. NO WIRE SHALL BE INSTALLED IN THE CONDUIT SYSTEM UNTIL THE CONDUIT SYSTEM IS COMPLETE. USE MINERALAC NO. 100 OR EQUIVALENT AS A LUBRICANT TO FACILITATE THE INSTALLATION OF THE CONDUCTORS IN THE CONDUIT SYSTEM.
6. MC CABLE WITH COPPER CONDUCTORS AND GROUND WIRE MAY BE USED WHERE PERMITTED.

CONDUIT

- ALL WIRING SHALL BE INSTALLED IN LISTED METALLIC CONDUIT EXCEPT AS PERMITTED IN OTHER SECTIONS. RGS, WITH A 20 MIL PVC COATING WILL BE USED WHEN IN CONTACT WITH EARTH. IMC MAY BE USED IN INDOOR LOCATIONS NOT IN CONTACT WITH THE EARTH. EMT MAY BE USED IN INDOOR LOCATIONS NOT IN CONTACT WITH EARTH, NOT IN CONCRETE, SLABS OR WALLS AND NOT SUBJECT TO DAMAGE. PVC MAY BE USED IN OR BELOW CONCRETE AND DIRECT BURIED IN EARTH. FLEXIBLE STEEL CONDUIT SHALL BE USED FOR INDOOR FINAL CONNECTIONS TO EQUIPMENT IN LENGTHS NOT TO EXCEED 72". LIQUID-TIGHT FLEXIBLE STEEL CONDUIT SHALL BE FOR OUTDOOR FINAL CONNECTIONS TO EQUIPMENT NOT TO EXCEED 48".
2. WHERE CONDUIT ENTERS OUTLET BOXES, FIXTURES OR CABINETS, FIRMLY FASTEN WITH STEEL SET SCREW, COMPRESSION CONNECTORS, OR DOUBLE LOCKNUTS FOR GRC. ALL CONNECTIONS SHALL HAVE BUSHINGS OR INSULATED THROUGH CONNECTORS. FIRMLY FASTEN CONDUIT TO THE BUILDING CONSTRUCTION. RUN EXPOSED CONDUIT PARALLEL TO THE BUILDING LINES, SUPPORTED BY APPROPRIATE HANGERS (UNISTRUT, T & B OR APLETON, OR EQUAL).
3. COVER METALLIC CONDUIT IN CONTACT WITH EARTH WITH POLYETHYLENE TAPE SPIRAL WRAPPED, 1/2 LAPPED TO PROVIDE 20 MIL THICKNESS. TAPE SHALL BE SCOTCH NO. 50 TAPE. CONDUIT AND DUCTS NOT UNDER BUILDINGS AND FEEDER DUCTS SHALL BE INSTALLED PER N.E.C. 300-5. MAKE JOINTS WITH COMPOUND TO BE WATERTIGHT.
4. SCHEDULE 40 PVC CONDUIT SHALL BE PERMITTED UNDERGROUND WITH PROPER FITTINGS, ALL UL APPROVED AND CEMENTED JOINTS. PENETRATIONS THROUGH FLOOR SLABS AND BENDS GREATER THAN 22" SHALL BE WRAPPED RIGID GALVANIZED STEEL ELBOWS.
5. FITTINGS AND CONDUIT BODIES SHALL BE STEEL. DIECAST FITTINGS ARE NOT ACCEPTABLE. CONDUIT SIZES SHALL BE AS REQUIRED BY CODE AND AS INDICATED OR SPECIFIED.
7. ALL EMPTY CONDUIT SYSTEMS SHALL HAVE A 200 LB. TEST NYLON PULL STRING TO FACILITATE INSTALLATION OF FUTURE WIRE.
8. WIRING, CONDUITS, AND OUTLETS SHALL BE CONCEALED WITH THE BUILDING STRUCTURE, EXCEPT THAT CERTAIN MOTORS AND LIGHTING FEEDER CONDUITS MAY BE RUN EXPOSED IN CERTAIN AREAS AS INDICATED ON THE DRAWINGS.
9. CONDUIT PENETRATION THROUGH ROOF SHALL HAVE ROOF FLASHING WITH CAULK TYPE COUNTER FLASHING SLEEVE. INSTALLATION SHALL BE WATERTIGHT.
10. CONDUITS SHALL BE ROUTED PARALLEL AND PERPENDICULAR TO THE STRUCTURE.

E. OUTLET, PULL, AND JUNCTION BOXES

- EACH SWITCH, LIGHT, RECEPTACLE OR OTHER OUTLET, SHALL BE PROVIDED WITH A CODE SIZED, STEEL OUTLET BOX. JUNCTION AND PULL BOXES SHALL BE METAL AND CODE SIZED.
- BOXES INSTALLED IN POURED CEMENT FLOORS SHALL BE FLUSH TYPE CAST IRON OR STEEL WITH WATERTIGHT GASKETED COVERS. WHERE BOXES ARE INSTALLED IN FLOORS WITH TILE OR CARPET FLOOR COVERING, COVERS SHALL BE OF THE RECESSED TYPE TO ACCOMMODATE THE FLOOR COVERING.
- BOXES INSTALLED FOR THE ALARM, COMPUTER, AND SECURITY SYSTEM SHALL BE PROVIDED WITH APPROPRIATE COVER PLATES.
- BOXES FOR TELEPHONE, COMPUTER, T.V., FIRE ALARM, SECURITY, AND SIMILAR SYSTEMS SHALL BE MINIMUM 2-1/8" DEEP.

G. WIRING DEVICES (COMMERCIAL)

- WALL SWITCHES SHALL BE SPECIFICATION GRADE AC SILENT TYPE SWITCHES, 20A 120/277 VOLT.
- RECEPTACLES SHALL BE SPECIFICATION GRADE, DUPLEX TYPE, NEMAS-20R, 20 AMPERE, 120VOLT GROUNDED TYPE. SPECIAL APPLICATION RECEPTACLES SHALL BE INDICATED ON PLANS. MOUNT WITH THE GROUND DOWN.
- DEVICE PLATES SHALL BE EQUAL TO SIERRA SMOOTH-LINE PLASTIC WALL PLATES. COLOR SHALL BE WHITE, UNLESS OTHERWISE NOTED.
- RECEPTACLES IN OUTDOOR AREAS AND LOCATIONS SHALL BE INSTALLED WITH A HINGED OUTLET COVER/ENCLOSURE CLEARLY MARKED AND U.L. LISTED SUITABLE FOR WET LOCATIONS WHILE IN USE, EQUAL TO TAYMAC SPECIFICATION GRADE.

H. SERVICE ENTRANCE SECTION

- THE SERVICE ENTRANCE EQUIPMENT SHALL BE AS INDICATED ON THE DRAWINGS. EQUIPMENT SHALL CARRY THE U.L. LABEL AND SHALL CONFORM TO THE POWER COMPANY REGULATIONS.
- SERVICE ENTRANCE EQUIPMENT SHALL BE PROVIDED WITH A FULLY RATED COPPER OR ALUMINUM BUS. HORIZONTALLY TAPERED BUSSING SHALL NOT BE ALLOWED.

I. DISTRIBUTION PANELS

- DISTRIBUTION PANELS SHALL BE PROVIDED WITH FULLY RATED COPPER OR ALUMINUM BUS. HORIZONTAL TAPERED BUSSING SHALL NOT BE ALLOWED.
- ACCEPTABLE MANUFACTURERS – CUTLER HAMMER, SIEMENS, SQUARE D OR GENERAL ELECTRIC
- FACTORY ASSEMBLED DEAD FRONT, METAL ENCLOSED, AND SELF-SUPPORTING SWITCH BOARD ASSEMBLY CONFORMING T NEMA PB 2 AND UL 891, AND COMPLETE FROM INCOMING LINE TERMINALS TO LOAD SIDE TERMINATIONS.
- LINE AND LOAD TERMINATIONS: ACCESSIBLE FROM FRONT ONLY OF THE SWITCH BOARD. SUITABLE FOR CONDUCTOR MATERIALS AND NUMBER OF CONDUCTORS USED.
- BUS CONNECTIONS: BOLTED. ACCESSIBLE FROM FRONT FOR MAINTENANCE. PROVIDE BELLEVILLE WASHERS FOR PROPERLY TORQUE ALL CONNECTIONS
- PROVIDE FULLY-RATED NEUTRAL BUS AND FULLY RATED GROUND BUS MATCHING MATERIAL USED FOR MAIN BUS.
- FUTURE PROVISIONS: FULLY EQUIP SPACES FOR FUTURE DEVICES WITH BUSSING AND BUS CONNECTIONS SUITABLY INSULATED AND BRACED FOR SHORT CIRCUIT CURRENTS. CONTINUOUS CURRENT RATING AS INDICATED ON DRAWINGS.
- ALL CIRCUIT BREAKERS SHALL BE BOLT-ON TYPE.

H. PANEL BOARDS

- CIRCUIT BREAKER TYPE AS INDICATED ON DRAWINGS. UNLESS INDICATED OTHERWISE, ALL PANELS SHALL HAVE PANEL BOARD TYPE CONSTRUCTION WITH BOLT-ON CIRCUIT BREAKERS FOR 3ø PANELS
- MANUFACTURERS SHALL BE GENERAL ELECTRIC, SQUARE D, SIEMENS, CUTLER-HAMMER WITH VOLTAGE, SIZES, AND RATINGS AS INDICATED ON DRAWINGS.
- THE CIRCUIT BREAKERS SHALL BE OPERABLE IN ANY POSITION AND BE REMOVABLE FROM THE FRONT OF THE PANEL BOARD WITHOUT DISTURBING THE ADJACENT UNITS. BRANCH BREAKERS SHALL BE OF SUCH DESIGN THAT COMBINATION OF SINGLE-POLE, DOUBLE-POLE, AND THREE-POLE BREAKERS CAN BE ASSEMBLED ON THE SAME PANEL. EACH BRANCH CIRCUIT SHALL BE CLEARLY NUMBERED. BRANCH AND MAIN TERMINALS SHALL BE SOLDERLESS TYPE. HANDLE TIES TO FORM MULTI-POLE BREAKERS NOT ACCEPTABLE.

K. LOAD CENTER

- CIRCUIT BREAKER TYPE AS INDICATED ON DRAWINGS. MANUFACTURERS SHALL BE GENERAL ELECTRIC, SQUARE D, SIEMENS, CUTLER-HAMMER/EATON WITH VOLTAGE, SIZES, AND RATINGS AS INDICATED ON DRAWINGS.
- THE CIRCUIT BREAKERS SHALL BE OPERABLE IN ANY POSITION AND BE REMOVABLE FROM THE FRONT OF THE PANEL BOARD WITHOUT DISTURBING THE ADJACENT UNITS. BRANCH BREAKERS SHALL BE OF SUCH DESIGN THAT COMBINATION OF SINGLE-POLE AND DOUBLE-POLE BREAKERS CAN BE ASSEMBLED ON THE SAME PANEL. EACH BRANCH CIRCUIT SHALL BE CLEARLY NUMBERED. BRANCH AND MAIN TERMINALS SHALL BE OF THE SOLDERLESS TYPE. HANDLE TIES TO FORM MULTI-POLE BREAKERS NOT ACCEPTABLE.
A.A.A. CIRCUIT BREAKERS SHALL BE PLUG-IN TYPE
3. WIRE TERMINATION FOR PANEL BOARDS AND CIRCUIT BREAKERS SHALL BE LISTED AS SUITABLE FOR 75 DEGREES C.
4. PROVIDE A TYPEWRITTEN CIRCUIT INDEX BEHIND CLEAR PLASTIC COVER ON INSIDE OF DOOR. INFORMATION SHALL INCLUDE ROOM AND TYPE LOAD SERVED. ALL CIRCUIT BREAKERS SHALL BE IDENTIFIED, INCLUDING SPARES. INDEX CARD FRAME SHALL BE METAL, SECURED TO DOOR. PANEL BOARDS/LOAD CENTERS TO BE PROVIDED WITH COPPER BUSSING ONLY.

L. LIGHTING FIXTURES

- PROVIDE ALL LIGHTING FIXTURES, WIRED AND CONNECTED. THE DRAWINGS INDICATE THE FIXTURES FOR EACH LOCATION. PROVIDE LAMP FOR ALL FIXTURES. THE LAMPS SHALL BE BY THE SAME MANUFACTURER. VERIFY CEILING CONSTRUCTION BEFORE ORDERING RECESSED UNITS. PROVIDE PLASTER FRAMES AND HANGERS AS REQUIRED. CEILING CONSTRUCTION, ARCHITECTURAL ACCESSORIES, VOLTAGE, AND DRIVERS TO MEET THE EXISTING CEILING CONDITION.

M. LIGHTING CONTROL

- FURNISH AND INSTALL TIME SWITCHES, PHOTOCELLS, CONTRACTORS AND FULL LIGHTING CONTROL SYSTEMS AS REQUIRED FOR LIGHTING CONTROLS INDICATED ON THE DRAWINGS.
- TIME SWITCHES SHALL BE EQUAL TO PARAGON, GENERAL ELECTRIC, TORK, OR INTERMATIC AND SHALL HAVE SIZE AND NUMBER OF POLES AS REQUIRED. PHOTOCELLS SHALL BE EQUAL TO TORK OR INTERMATIC WITH VOLTAGE AS INDICATED.

J. TELEPHONE AND CABLE TELEVISION SYSTEMS

- TELEPHONE WALL OUTLETS SHALL CONSIST OF NO LESS THAN 2-1/8" DEEP BOXES MOUNTED 18" ABOVE THE FLOOR UNLESS OTHERWISE INDICATED. PROVIDE A TERMINAL MOUNTING BOARD FOR THE INCOMING SERVICE CABLE.
- CABLE TELEVISION OUTLETS SHALL CONSIST OF NO LESS THAN 2-1/8" DEEP BOXES MOUNTED 18" ABOVE THE FLOOR UNLESS OTHERWISE INDICATED. PROVIDE A TERMINAL MOUNTING BOARD FOR THE INCOMING SERVICE CABLE.

K. GUARANTEE

- GUARANTEE ALL MATERIAL FURNISHED AND ALL WORKMANSHIP PERFORMED FOR A PERIOD OF ONE YEAR FROM DATE OF FINAL ACCEPTANCE OF WORK. ANY DEFECTS DEVELOPING WITHIN THIS PERIOD, TRACEABLE TO MATERIAL FURNISHED AS A PART OF THIS SECTION OR WORKMANSHIP PERFORMED HEREUNDER, SHALL BE MADE GOOD AT NO EXPENSE TO THE OWNER.

L. REMODELING WORK

- THIS PROJECT INVOLVES CONSTRUCTION INSIDE AN EXISTING STRUCTURE. CONTRACTORS, BY SUBMITTING A BID ARE DEEMED TO BE COMPLETELY FAMILIAR WITH THE EXISTING CONDITIONS OF THE BUILDING AS IT INFLUENCES THE WORK DESCRIBED. NO CLAIMS FOR EXTRA COMPENSATION WILL BE CONSIDERED FOR EXISTING CONDITIONS VISIBLE OR REASONABLY INFERRABLE FROM A CAREFUL EXAMINATION OF THE EXISTING BUILDING CONDITIONS.
- CONTRACTOR SHALL INSPECT THE EXISTING FIELD CONDITIONS AT THE SITE AND THE CONTRACT DOCUMENTS PRIOR TO THE START OF ANY WORK TO DETERMINE WHAT EFFECT THE EXISTING CONDITIONS WILL HAVE ON THE WORK POTENTIAL. CONTRACTOR SHALL REPORT DISCREPANCIES TO THE ARCHITECT AND INCLUDE IN THE BID ALL COSTS REQUIRED TO MAKE THE WORK MEET EXISTING CONDITIONS.
- DEMOLITION: DISCONNECT, DEMOLISH, AND REMOVE ABANDONED MATERIALS AND EQUIPMENT INDICATED TO BE REMOVED AND NOT INDICATED TO BE SALVAGED OR REMAIN.
- DISPOSAL AND CLEANUP: REMOVE FROM THE SITE AND LEGALLY DISPOSE OF DEMOLISHED MATERIALS AND EQUIPMENT NOT INDICATED TO BE SALVAGED.
- PROTECT MATERIALS INDICATED TO REMAIN.

M. FIRE SEALING NOTES

- COORDINATE CONSTRUCTION OF OPENINGS AND PENETRATING ITEMS TO ENSURE THAT THROUGH-PENETRATION FIRESTOP SYSTEMS ARE INSTALLED ACCORDING TO SPECIFIED AND APPLICABLE UL REQUIREMENTS.
- COORDINATE SIZING OF SLEEVES, OPENINGS, CORE-DRILLED HOLES, OR CUT OPENINGS TO ACCOMMODATE THROUGH-PENETRATION FIRESTOP SYSTEMS.
- DO NOT COVER UP THROUGH-PENETRATION FIRESTOP SYSTEM INSTALLATIONS UNTIL EXAMINED BY INSPECTOR, IF REQUIRED BY AUTHORITIES HAVING JURISDICTION.
- COMPATIBILITY: PROVIDE THROUGH-PENETRATION FIRESTOP SYSTEMS THAT ARE COMPATIBLE WITH ONE ANOTHER; WITH THE SUBSTRATES FORMING OPENINGS; AND WITH THE ITEMS, IF ANY, PENETRATING THROUGH-PENETRATION FIRESTOP SYSTEMS, UNDER CONDITIONS OF SERVICE AND APPLICATION, AS DEMONSTRATED BY THROUGH-PENETRATION FIRESTOP SYSTEM MANUFACTURER BASED ON TESTING AND FIELD EXPERIENCE.
- PROVIDE COMPONENTS FOR EACH THROUGH-PENETRATION FIRESTOP SYSTEM THAT ARE NEEDED TO INSTALL FILL MATERIALS. USE ONLY COMPONENTS SPECIFIED BY THROUGH-PENETRATION FIRESTOP SYSTEM MANUFACTURER AND APPROVED BY QUALIFIED TESTING AND INSPECTING AGENCY FOR FIRESTOP SYSTEMS INDICATED.
- PROVIDE SLEEVES THROUGH ALL FIRE-RATED WALLS AND FILL VOIDS SURROUNDING SLEEVES AND INTERIOR TO SLEEVES AROUND PIPING WITH FIRE STOP PUTTY WITH U.L. LISTED 3 HOUR RATING INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS.
- FIRE SEAL ALL PIPING, CONDUIT, CABLE, ETC PENETRATIONS ROUTED THROUGH FIRE RATED WALLS.
- PROVIDE FIRE RATED ENCLOSURES OR WRAPS ON LIGHT FIXTURES AND OTHER ITEMS PENETRATING FIRE RATED CEILINGS, FLOOR/CEILING/ CEILING/ROOF ASSEMBLIES TO MAINTAIN UL LISTING FOR CONSTRUCTION.

SYMBOLS LEGEND

NOTE: THIS IS A MASTER LEGEND AND NOT ALL SYMBOLS, ETC, ARE NECESSARILY USED ON THE DRAWINGS.

LIGHTING FIXTURES – SYMBOL/LETTER INDICATES LIGHT FIXTURE AS INDICATED ON FIXTURE SCHEDULE

- LED FIXTURE (SEE LIGHTING FIXTURE SCHEDULE)
- FIXTURE WITH EMERGENCY BATTERY DRIVER UNIT
TRACK LIGHT
- DOWNLIGHT FIXTURE WITH EMERGENCY BATTERY DRIVER UNIT
- WALL MOUNTED FIXTURE WITH EMERGENCY BATTERY DRIVER UNIT
- PENDANT MOUNTED FIXTURE WITH EMERGENCY BATTERY DRIVER UNIT
- DOWNLIGHT FIXTURE
- WALL MOUNTED FIXTURE
- PENDANT MOUNTED FIXTURE
- WALL WASHER
- SINGLE FACE EXIT SIGN – UNIVERSAL MOUNTED
- SINGLE FACE EXIT SIGN W/ DIRECTIONAL ARROWS – UNIVERSAL MTD
- DOUBLE FACE EXIT SIGN W/ DIRECTIONAL ARROWS – UNIVERSAL MTD
- DUAL HEADED EMERGENCY UNIT
- COMBO DUAL HEADED EMERGENCY AND EXIT SIGN UNIT

LIGHTING CONTROLS

- S SINGLE POLE SWITCH @ +48" UNLESS NOTED
- Sabc SWITCH BANK @ +48" UNLESS NOTED. LOWER CASE LETTER INDICATES FIXTURE CONTROLLED.
- S3 3-WAY SWITCH @ +48" UNLESS NOTED
- S4 4-WAY SWITCH @ +48" UNLESS NOTED
- Sd DIMMER SWITCH – SIZE AS REQUIRED @ +48" UNLESS NOTED
- Sm MANUAL MOTOR STARTER
- Sos WALL SWITCH WITH OCCUPANCY SENSOR. DIGITAL LOW VOLTAGE WALL SWITCH. SWITCH @ +48" UNLESS NOTED.
- SLV TWO BUTTON DIGITAL LOW VOLTAGE WALL SWITCH. PROVIDES ON/OFF/O-10V DIMMING. SWITCH @ +48" UNLESS NOTED. PROVIDE EXTRA CONTROL CABLES NEEDED TO FIXTURE CONTROLLED.
- CS LIGHTING CONTROLS CEILING MOUNT OCCUPANCY SENSOR
- PC LIGHTING CONTROLS POWER PACK
- PH PHOTOCELL
- TC TIMECLOCK

POWER DISTRIBUTION

- SWITCHBOARD, MOTOR CONTROL CENTER OR DISTRIBUTION BOARD
- 277/480V, 3 PHASE, 4 WIRE PANELBOARD, UNO
- 120/208V, 3 PHASE, 4 WIRE PANELBOARD, UNO
- 120/240V, 1 PHASE, 3 WIRE PANELBOARD, UNO
- TRANSFORMER

POWER DEVICES

- SPECIAL HEAVY DUTY RECEPTACLE – SIZE AS NOTED. @ +18" UNLESS NOTED
- 1/2 SWITCHED RECEPTACLE @ +18" UNLESS NOTED
- FIRE RATED POKE THRU WITH TYPE INDICATED
- FLUSH FLOOR BOX WITH TYPE INDICATED
- SINGLE RECEPTACLE @ +18" UNLESS NOTED
- DUPLEX RECEPTACLE @ +18" UNLESS NOTED
- DOUBLE DUPLEX RECEPTACLE @ +18" UNLESS NOTED
- DUPLEX RECEPTACLE INSTALLED ABOVE COUNTERTOP
- GFCI-RATED DUPLEX RECEPTACLE
- ARC FAULT RATED DUPLEX RECEPTACLE
- TAMPER RESISTANT RATED DUPLEX RECEPTACLE
- DUPLEX RECEPTACLE WITH WEATHERPROOF COVERPLATE @ +18" UNLESS NOTED
- JUNCTION BOX
- DISCONNECT SWITCH – SIZE AND TYPE NOTED
- COMBINATION FUSED STARTER DISCONNECT SWITCH FUSE SIZE AS INDICATED, STARTER SIZE "1"

AUXILIARY SYSTEMS


- MECHANICAL EQUIP. CONNECTION, SEE SCHED. ON MECH. PLAN
- TELEPHONE OUTLET @ +18" UNLESS NOTED
- DATA OUTLET @ +18" UNLESS NOTED
- COMBINATION TELEPHONE/DATA OUTLET @ +18" UNLESS NOTED
- TELEVISION OUTLET @ +60" UNLESS NOTED
- SMOKE DETECTOR
- HEAT DETECTOR
- DUCT SMOKE DETECTOR
- REMOTE TEST STATION WITH INDICATING LIGHT. MOUNT AT 48" AFF UNO.
- AUXILIARY SYSTEM TERMINAL CABINET

GENERAL

- CONDUIT RUN CONCEALED IN WALL OR ABOVE CEILING
- CONDUIT RUN BELOW FLOOR OR GRADE
- HOMERUN TO PANELBOARD, INFORMATION AT ARROWS ARE CIRCUIT NUMBERS AND PANELBOARD FOR TERMINATION. REFER TO ASSOCIATED NOTE FOR BRANCH CIRCUIT CONDUCTOR SIZES.
- INDICATES 1/2" CONDUIT CONCEALED IN CEILING OR WALL WITH (3) CONDUCTORS. (1) PHASE, (1) NEUTRAL AND (1) GROUND WIRE. ALL ARE #12 AWG UNLESS NOTED OTHERWISE.
- (E) OR ETR: DENOTES EXISTING ITEM/EQUIPMENT TO REMAIN



MEP ENGINEER



MO COA NO. 2012008786 / KS COA NO. E-2818
1925 CENTRAL ST., STE. 201
KANSAS CITY, MO 64108
phone: (816) 272-5288, email: jsmothers@jsscengineers.com

PERFECT PROMOTIONS

1469 SW MARKET STREET
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



project number 22-083

date 05.25.2022

issued for PERMIT

rev date description

ELECTRICAL
SYMBOLS AND
SPECIFICATIONS

sheet number


E100

GENERAL NOTES

- A. DRAWINGS ARE DIAGRAMMATIC AND SHALL NOT BE SCALED. REFER TO ARCHITECTURAL PLANS OR FIELD MEASUREMENTS FOR DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE LATEST ADOPTED EDITION OF THE NATIONAL ELECTRICAL CODE (NFPA 70) AND ALL LOCAL BUILDING CODES AND AMENDMENTS.
- C. ALL ROOF AND WALL PENETRATIONS SHALL BE COORDINATED WITH THE GENERAL CONTRACTOR. PROVIDE ALL REQUIRED SLEEVES, FLASHINGS, CURBS, REINFORCED ANGLES, SUPPORTING FRAMES, ETC. UNLESS THEY ARE SPECIFICALLY CALLED OUT TO BE FURNISHED BY OTHERS.
- D. COORDINATE ALL WORK WITH OTHER TRADES AND EXISTING CONDITIONS AS REQUIRED TO PROPERLY INSTALL ALL SYSTEMS AS INTENDED, WITHIN THE CONFINES OF THE SPACE AVAILABLE, AND WITHOUT INTERFERENCES.
- E. THIS CONTRACTOR SHALL PERFORM ALL WORK INDICATED AND/OR AS REQUIRED FOR THE PROPER INSTALLATION AND OPERATION OF THE ELECTRICAL SYSTEMS.
- F. ALL WIRING SHALL BE IN APPROVED RACEWAY.
- G. WIRE SIZE SHALL BE MINIMUM #12 AWG, THWN SOLID COPPER UNLESS OTHERWISE NOTED. PROVIDE GROUND WIRE WHERE REQUIRED BY CODE. INCREASE WIRE SIZE TO COMPENSATE FOR VOLTAGE DROP WHERE TOTAL LENGTH OF ANY BRANCH EXCEEDS 100 FEET.
- H. MAXIMUM NUMBER OF UNGROUNDED WIRES IN ANY CONDUIT SHALL BE THREE. ADDITIONAL WIRES ARE ACCEPTABLE IF WIRE SIZE IS INCREASED TO ALLOW FOR DERATING PER CODE. PROVIDE ADDITIONAL WIRES FOR SWITCHING AS REQUIRED.
- I. FIRE ALARM, AUDIO/VIDEO AND SURVEILLANCE SYSTEMS BY OTHERS.
- J. CONNECT ALL EXIT SIGNS AND EMERGENCY LIGHTING UNITS TO THE INDICATED CIRCUIT WITH A SEPARATE AND UN-SWITCHED CONDUCTOR BYPASSING ALL CONTROLS AND CONTACTORS. REFER TO MANUFACTURER'S WRITTEN INSTRUCTIONS FOR PROPER INSTALLATION AND TESTING.
- K. ROUTE ALL EXPOSED, RIGID CONDUIT TIGHT TO STRUCTURE, PARALLEL TO BUILDING LINES AND IN UNISTRUT CABLE/PIPE TRAY WHERE POSSIBLE. COORDINATE CONDUIT ROUTING AND INSTALLATION WITH OTHER TRADES PRIOR TO ROUGH-IN. SUPPORT CONDUIT FROM STRUCTURE NOT ROOF DECK. MAINTAIN 2" MIN SPACING FROM BOTTOM OF ROOF DECK TO PREVENT ROOFING SCREWS FROM PENETRATING CONDUITS.
- L. ALL FIXTURES AND DEVICES EXISTING AND NOT NOTED FOR WORK IN THIS SCOPE ARE TO REMAIN.

KEYED PLAN NOTES

1. LIGHTING FIXTURES AND CONTROLS IN THIS ROOM ARE EXISTING TO REMAIN.
2. MAKE CONNECTION TO EXIT/EMERGENCY LIGHT VIA UNSWITCHED HOT CONDUCTOR.
3. CEILING MOUNTED OCCUPANCY SENSOR. SENSORWORX SWX-200 SERIES OR PRE-BID APPROVED EQUAL. MAKE ALL CONNECTIONS ACCORDING TO MANUFACTURER'S LITERATURE AND NEC REQUIREMENTS.
4. LIGHTING CONTROLS POWER PACK. SENSORWORX SWX-900 SERIES OR PRE-BID APPROVED EQUAL. MAKE ALL CONNECTIONS ACCORDING TO MANUFACTURER'S LITERATURE AND NEC REQUIREMENTS.
5. WALL SWITCH OCCUPANCY SENSOR. SENSORWORX SWX-100 SERIES OR PRE-BID APPROVED EQUAL. MAKE ALL CONNECTIONS ACCORDING TO MANUFACTURER'S LITERATURE AND NEC REQUIREMENTS.




LIGHTING PLAN

SCALE : 1/4" = 1'-0"

1



MEP ENGINEER



MO COA NO. 2012008786 / KS COA NO. E-2818
1925 CENTRAL ST., STE. 201
KANSAS CITY, MO 64108
phone: (816) 272-5285, email: jsmothers@jsscengineers.com

PERFECT PROMOTIONS

1469 SW MARKET STREET
LEE'S SUMMIT, MO 64081
HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



project number 22-083

date 05.25.2022

issued for PERMIT

rev date description

ELECTRICAL
PLANS

sheet number


E101

GENERAL NOTES

- A. DRAWINGS ARE DIAGRAMMATIC AND SHALL NOT BE SCALED. REFER TO ARCHITECTURAL PLANS OR FIELD MEASUREMENTS FOR DIMENSIONS.
- B. ALL WORK SHALL COMPLY WITH THE LATEST ADOPTED EDITION OF THE NATIONAL ELECTRICAL CODE (NFPA 70) AND ALL LOCAL BUILDING CODES AND AMENDMENTS.
- C. ALL ROOF AND WALL PENETRATIONS SHALL BE COORDINATED WITH THE GENERAL CONTRACTOR. PROVIDE ALL REQUIRED SLEEVES, FLASHINGS, CURBS, REINFORCED ANGLES, SUPPORTING FRAMES, ETC. UNLESS THEY ARE SPECIFICALLY CALLED OUT TO BE FURNISHED BY OTHERS.
- D. COORDINATE ALL WORK WITH OTHER TRADES AND EXISTING CONDITIONS AS REQUIRED TO PROPERLY INSTALL ALL SYSTEMS AS INTENDED, WITHIN THE CONFINES OF THE SPACE AVAILABLE, AND WITHOUT INTERFERENCES.
- E. THIS CONTRACTOR SHALL PERFORM ALL WORK INDICATED AND/OR AS REQUIRED FOR THE PROPER INSTALLATION AND OPERATION OF THE ELECTRICAL SYSTEMS.
- F. ALL WIRING SHALL BE IN APPROVED RACEWAY.
- G. WIRE SIZE SHALL BE MINIMUM #12 AWG, THWN SOLID COPPER UNLESS OTHERWISE NOTED. PROVIDE GROUND WIRE WHERE REQUIRED BY CODE. INCREASE WIRE SIZE TO COMPENSATE FOR VOLTAGE DROP WHERE TOTAL LENGTH OF ANY BRANCH EXCEEDS 100 FEET.
- H. MAXIMUM NUMBER OF UNGROUNDED WIRES IN ANY CONDUIT SHALL BE THREE. ADDITIONAL WIRES ARE ACCEPTABLE IF WIRE SIZE IS INCREASED TO ALLOW FOR DERATING PER CODE. PROVIDE ADDITIONAL WIRES FOR SWITCHING AS REQUIRED.
- I. FIRE ALARM, AUDIO/VIDEO AND SURVEILLANCE SYSTEMS BY OTHERS.
- J. CONNECT ALL EXIT SIGNS AND EMERGENCY LIGHTING UNITS TO THE INDICATED CIRCUIT WITH A SEPARATE AND UN-SWITCHED CONDUCTOR BYPASSING ALL CONTROLS AND CONTACTORS. REFER TO MANUFACTURER'S WRITTEN INSTRUCTIONS FOR PROPER INSTALLATION AND TESTING.
- K. ROUTE ALL EXPOSED, RIGID CONDUIT TIGHT TO STRUCTURE, PARALLEL TO BUILDING LINES AND IN UNISTRUT CABLE/PIPE TRAY WHERE POSSIBLE. COORDINATE CONDUIT ROUTING AND INSTALLATION WITH OTHER TRADES PRIOR TO ROUGH-IN. SUPPORT CONDUIT FROM STRUCTURE NOT ROOF DECK. MAINTAIN 2" MIN SPACING FROM BOTTOM OF ROOF DECK TO PREVENT ROOFING SCREWS FROM PENETRATING CONDUITS.
- L. ALL FIXTURES AND DEVICES EXISTING AND NOT NOTED FOR WORK IN THIS SCOPE ARE TO REMAIN.

KEYED PLAN NOTES

1. POWER/DATA IN THIS ROOM IS EXISTING TO REMAIN.
2. PROVIDE BACKBOX FOR OWNER-PROVIDED 8-WIRE FURNITURE POWER FEED. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH OWNER PRIOR TO CONSTRUCTION.
3. RECEPTACLE FOR MICROWAVE INSTALLED BELOW COUNTERTOP. INSTALL RECEPTACLE IN AN ACCESSIBLE MANNER.
4. RECEPTACLE FOR DISHWASHER INSTALLED BELOW COUNTERTOP. INSTALL RECEPTACLE IN AN ACCESSIBLE MANNER.
5. CONDUIT ROUTED DOWN IN WALL TO WIREMOLD RACEWAY.
6. RECEPTACLE FOR DISPOSAL INSTALLED BELOW COUNTERTOP AND SWITCH TO TURN DISPOSAL ON/OFF INSTALLED ABOVE COUNTER. INSTALL RECEPTACLE IN AN ACCESSIBLE MANNER.
7. ELECTRICAL WIRING TO BE INSTALLED IN WIREMOLD RACEWAY AND ROUTED TO SURFACE MOUNTED FLOOR BOX. WIREMOLD RACEWAY TO BE LEGRAND CONNECTRAC OR EQUAL. BASIS OF DESIGN CONNECTRAC SPECIFICATION: CTXPO.1-09-251c-SV WITH QUAD POWER/DATA RECEPTACLE AND OTHER ACCESSORIES AS NECESSARY TO INSTALL ACCORDING TO MANUFACTURER'S LITERATURE.
8. EXISTING PANELBOARDS TO REMAIN. REFER TO PANELBOARD SCHEDULES ON SHEET E201 FOR MORE INFORMATION.




POWER PLAN

SCALE : 1/4" = 1'-0"

1



MEP ENGINEER



MO COA NO. 2012006786 / KS COA NO. E-2818
1925 CENTRAL ST., STE. 201
KANSAS CITY, MO 64108
phone: (816) 272-5285, email: jsmothers@jsscengineers.com

PERFECT PROMOTIONS

1469 SW MARKET STREET
LEE'S SUMMIT, MO 64081
HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



project number 22-083

date 05.25.2022

issued for PERMIT

rev date description


ELECTRICAL
PLANS

sheet number

E102



MEP ENGINEER



MO COA NO. 2012006786 / KS COA NO. E-2818
1925 CENTRAL ST., STE. 201
KANSAS CITY, MO 64108
phone: (816) 272-5285, email: jsmothers@jscengineers.com

PERFECT PROMOTIONS

1469 SW MARKET STREET
LEE'S SUMMIT, MO 64081

HIVE DESIGN COLLABORATIVE, INC.
1617 WALNUT STREET, KANSAS CITY, MO 64108
816.581.6363

COPYRIGHT © 2022
HIVE DESIGN COLLABORATIVE, INC.

seal/signature



project number 22-083

date 05.25.2022

issued for PERMIT

rev date description

ELECTRICAL
SCHEDULES AND
SINGLE LINE

sheet number

E201

ELECTRICAL LIGHTING SCHEDULE (OR EQUAL, VERIFY ALL SELECTIONS AND FINISHES WITH OWNER OR ARCHITECT PRIOR TO ORDERING).

FIXTURE TYPE	MANUFACTURER		VOLT AMPS	MOUNTING	LAMP TYPE	REMARKS	VOLT
	NAME	CATALOG NUMBER					
A	MATCH EXISTING 2x4	MATCH EXISTING 2x4	30	RECESSED	INCLUDED LED	MATCH EXISTING 2x4 LED FIXTURE ALREADY INSTALLED IN TENANT SPACE	120
B	BARBICAN	DRUM	24	PENDANT	INCLUDED LED	24" DIAMETER LED DRUM PENDANT - 3000K - DRUM COLOR TO BE SELECTED BY ARCHITECT	120
C	KUZCO	PIAZZA PD85124	60	PENDANT	INCLUDED LED	24" x 24" LED PENDANT - 3000K - BLACK FINISH	120
D	COOPER	CORELITE CONTINUA SQ4	20	PENDANT	INCLUDED LED	4" x 72" LED SUSPENDED FIXTURE - 3500K	120
ER	EXISTING DOWNLIGHT - RELOCATED	EXISTING	25	RECESSED	INCLUDED LED	EXISTING DOWNLIGHT TO BE RELOCATED - MAKE CONNECTION IN NEW LOCATION	120
ETR	EXISTING DOWNLIGHT TO REMAIN	EXISTING	25	RECESSED	INCLUDED LED	EXISTING DOWNLIGHT TO REMAIN - RECONNECT TO POWER/CONTROL WIRING AS NECESSARY	120
	LITHONIA	ELM6L	10.6	SURFACE	INCLUDED LED	EMERGENCY LIGHTING UNIT WITH 90 MIN. BATTERY PACK	120/277
	LITHONIA	LHQM	5	SURFACE	INCLUDED LED	EMERGENCY EXIT EGRESS COMBO LIGHTING UNIT WITH RED FACE EXIT SIGN AND 90 MIN. BATTERY PACK	120/277
	LITHONIA	LE-S-W-1/2-R-EL-N	5	UNIVERSAL	INCLUDED LED	RED LED EXIT SIGN WITH DIRECTIONAL ARROWS AND 90 MIN BATTERY BACK-UP	120

LIGHTING FIXTURE SCHEDULE

SCALE : NO SCALE

3

PANELBOARD: P (EXISTING)										FED FROM: Utility										LINE-SIDE LUGS: MECHANICAL									
BUS AMPS: 400A										AIC RATING: CONTRACTOR TO VERIFY AND NOTIFY EOR										EQUIPMENT GROUND BUS									
MAIN SIZE/TYPE: MLO										SERVES: Perfect Promotions																			
VOLTS/PHASE: 208Y/120V, 3PH, 4W										MOUNTING: SURFACE																			
SECTION: 1										LOCATION: IT Closet																			
CKT NO.	DESCRIPTION	VOLTAMPS/PHASE			WIRE NO.	BKR AMP	P	BKR AMP	WIRE NO.	VOL TAMPS/PHASE			DESCRIPTION	CKT NO.															
		A	B	C						A	B	C																	
1	LTG - LIGHTS	500			12	20	1	1	20	12	720		RCPT - ACCOUNTING	2															
3	LTG - LIGHTS		600		12	20	1	1	20	12		720	RCPT - OFFICE 104	4															
5	RCPT - BREAKROOM/STORAGE			540	12	20	1	1	20	12		720	RCPT - OFFICE 103	6															
7	RCPT - BREAKROOM	1,000			12	20	1	1	20	12	1,300		RCPT - CONFERENCE	8															
9	RCPT - MICROWAVE		1,500		12	20	1	1	20	12		1,500	PWR - NEON SIGN	10															
11	***RCPT - DISHWASHER			1,176	12	20	1	1	20	12			720	RCPT - LOBBY	12														
13	RCPT - DISPOSAL	1,350			12	20	1	1	20	12	1,500		RCPT - PRINTER/COPIER	14															
15	RCPT - BREAKROOM		1,000		12	20	1	1	20	12		500	RCPT - MAIL/LABELING	16															
17	RCPT - REFRIGERATOR			800	12	20	1	1	20	12		840	RCPT - HUDDLE 110	18															
19	RCPT - CEO	1,080			12	20	1	1	20	12		840	RCPT - HUDDLE 111	20															
21	SPARE				20	1	1	20	12			720	RCPT - COLLAS SPACE	22															
23	SPARE				20	1	1	20	12				SPARE	24															
25	SPARE				20	1	1	20	12	250			EMERGENCY LIGHTS	26															
27	SPARE				20	1	1	20					SPARE	28															
29	SPARE				20	1	1	20					SPARE	30															
31	SPARE				20	2	1	20					SPARE	32															
33	SPARE				20	1	1	20	12		900		I.T.	34															
35	SPARE				20	1	1	20					SPARE	36															
37	SPARE				20	2	1	20					SPARE	38															
39	SPARE				20	1	1	20					SPARE	40															
41	GFI RECEPTACLE ON ROOF			360	12	20	1	1	20				SPARE	42															
SUBTOTAL		3,910	3,100	2,876						20,460	19,940	17,610	SUBTOTAL																
TOTAL PHASE A - VA		24,370			LOAD	CONN. VA	DF		LOAD		CONN. VA	DF																	
AMPS		203			COOLING	40,320	1.00		REFRIG			1.00																	
TOTAL PHASE B - VA		23,040			HEATING				SIGN/DISP			1.25																	
AMPS		192			LIGHTING	1,600	1.25		KITCHEN			1.00																	
TOTAL PHASE C - VA		20,486			RECEPTACLES	25,776	1.0/5		EXISTING			1.25																	
AMPS		171			MOTORS		1.00		LRG MOTOR			1.25																	
TOTAL PN/BD - VA		67,896			SUPP HEAT		1.00		SHOW/WNDW			1.00	TOTAL DEMAND																
AMPS		188			MISC EQUIP	200	1.00		LTG TRACK			1.00	60,408 VA 168 A																
PANELBOARD NOTES																													
DESCRIPTION IN ITALICS = EXISTING LABELED LOAD TO REMAIN																													
*** = GFCI-TYPE BREAKER																													

ELECTRICAL PANEL SCHEDULES

SCALE : NO SCALE

2

PANELBOARD: P1 (EXISTING)										FED FROM: P				LINE-SIDE LUGS: MECHANICAL EQUIPMENT GROUND BUS			
BUS AMPS: 400A MAIN SIZE/TYPE: MLO VOLTS/PHASE: 208Y/120V, 3PH, 4W										AIC RATING: CONTRACTOR TO VERIFY AND NOTIFY EOR SERVES: Perfect Promotions MOUNTING: SURFACE LOCATION: IT Closet							
SECTION: 1																	
CKT NO.	DESCRIPTION	VOLTAMPS/PHASE			WIRE NO.	BKR AMP	P	BKR AMP	WIRE NO.	VOLTAMPS/PHASE			DESCRIPTION	CKT NO.			
		A	B	C						A	B	C					
1	HALL/BATH LIGHTS	250			12	20	1			720			PWR - FURN FEED 1.1,2,3	2			
3	SPARE				20	1	3	20	12		720			4			
5	EMERGENCY LIGHTS			250	12	20	1				720			6			
7	SPARE				20	1	1	20	12		720		PWR - FURN FEED 1.4	8			
9	SPARE				20	1					720			10			
11	SPARE				20	1	3	20	12			720	PWR - FURN FEED 2.1,2,3	12			
13	SPARE				20	1				720				14			
15	SPARE				20	1	1	20	12		720		PWR - FURN FEED 2.4	16			
17	SPARE				20	1	1	20					SPARE	18			
19	SPARE				20	1	1	20					SPARE	20			
21	SPARE				20	1	1	20					SPARE	22			
23	SPARE				20	1	1	20	12			200	ALARM	24			
25	SPARE				20	1				3,840				26			
27	SPARE				20	2	3	40	8		3,840		SOUTH RTU	28			
29	SPARE				20	1					3,840			30			
31	SPARE				20	1				4,800				32			
33	SPARE				20	1	3	50	6		4,800		NORTHWEST RTU	34			
35	SPARE				20	1					4,800			36			
37	SPARE				20	1				4,800				38			
39	SPARE				20	3	3	50	6		4,800		NORTHEAST RTU	40			
41	SPARE										4,800			42			
SUBTOTAL		250		250						15,600	15,600	15,080	SUBTOTAL				
TOTAL PHASE A - VA		15,850	LOAD		CONN. VA		DF	LOAD		CONN. VA		DF					
AMPS		132	COOLING		40,320		1.00	REFRIG				1.00					
TOTAL PHASE B - VA		15,600	HEATING					SIGN/DISP				1.25					
AMPS		130	LIGHTING		500		1.25	KITCHEN				1.00					
TOTAL PHASE C - VA		15,330	RECEPTACLES		5,760		1.0/5	EXISTING				1.25					
AMPS		128	MOTORS				1.00	LPG MOTOR				1.25					
TOTAL PN/BD - VA		46,780	SUPP HEAT				1.00	SHOW WNDW				1.00	TOTAL DEMAND				
AMPS		130	MISC EQUIP		200		1.00	LTG TRACK				1.00	46,905 VA 130 A				
PANELBOARD NOTES																	
DESCRIPTION IN ITALICS = EXISTING LABELED LOAD TO REMAIN																	

ELECTRIC SERVICE SINGLE LINE DIAGRAM IS EXISTING TO REMAIN. NO MODIFICATIONS
ARE BEING MADE TO THE ELECTRICAL SERVICE DISTRIBUTION EQUIPMENT IN THIS SCOPE.

SINGLE LINE DIAGRAM

SCALE : NO SCALE

1